

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/CNG/2018/SZ/ 1060

Dated: .....14/05/18

**FIRE SAFETY CERTIFICATE**

Certified that CNG Dispensing Station located at Nehru Place, New Delhi, comprised of Single Story building Owned/Occupied by Indraprastha Gas Limited was issued FSC by this department vide letter No F.6/DFS/MS/CNG/2015/SZ/1939 Dated 29-10-2015. The premises was re-inspected by the officer concerned of this department on 20/04/2018 in the presence of Mr. Ravinder (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class 'Hazardous' (CNG Pump) as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 of Delhi Fire Service Rules, 2010 and subject to compliance of the conditions mentioned below.

Issued on 14/05/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  


Copy to: -

1. Sh. Alok Sharma, Chief General Manager (Fire & Safety), IGL Bhawan, Plot No. 4, Community Centre, RK Puram, Sector-9, New Delhi-110022
2. The Addl. Comm. of Police (Lic.), First floor, P.S. Defence Colony, New Delhi-110049

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/12

INSPECTION REPORT				
1	Name & Address of the Building	CNG Dispensing Station, Nehru Place, New Delhi.		
2	Type of Occupancy	Hazardous 'Group-J'		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/CNG/2015/SZ/1939 Dated 29-10-2015		
6	Fire Safety Directives Letter No	F.5 (3A)/DFS/CNG/2000/132 Dated 29-03-2000		
7	Date of Inspection	20-04-2018		
8	Name of the Inspecting Officers	R.N. Singh, ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Ravinder (Manager)		
10	Year of construction	2000-01		
11	Applicant letter No.	IGL/F&S/2018/15/53 dated 02-04-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	6 mtr	Provided	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement.	N/A	N/A	N/A
	<b>b) Width of Staircase</b>			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	N/A	N/A	N/A
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	<b>Smoke Management system.</b>			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	29 Nos	MR
	• Types	CO2 & DCP	DCP (75kg)-05, DCP (10kg)-18, CO2 (4.5kg)-06	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	N/A	N/A	N/A
	• Length of hose-reel hose.	N/A	N/A	N/A
	• Nozzle Diameter	N/A	N/A	N/A

N/19

7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	Gas & flame	Provided in compressor	MR
		Required	Ground floor	MR
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Technician room	MR
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of main pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Head of main pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Number of main pumps.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Jockey Pump output.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Jockey Pump head.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Standby Pump output.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Standby Pump head.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Auto Starting/Manual Stopping.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump house access.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Head of pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Power supply.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Auto starting of pump.</li> </ul>	N/A	N/A	N/A
14.	<b>Captive water storage for Fire Fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> <li>Overhead tank capacity.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15.	<b>No Smoking Signage.</b>	Required	Provided in Hindi & English	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	<b>Standby Power Supply</b>	N/A	Provided DG Set	N/A
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location</li> </ul>	N/A	N/A	N/A

N/14

19.	<b>Fire Control Room.</b>	<ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
			N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	Required	Co2 flooding system connected through detectors provided in each compressor unit	MR	

The fire protection system provided in retail outlet area were checked and found functional at the time of inspection. "No Smoking" sign boards were found displayed both in Hindi & English at conspicuous places. No loose electrical wiring was seen in the premises.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/CNG/2015/SZ/1939 Dated 29-10-2015, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*R.N. Singh*  
21/4/18

Signature of the Inspecting Officer  
Name: R.N. Singh  
Designation: ADO (BCP)

DO (SD)

*Anilash*  
23/4/18

*Dy. CPO (S2)*

*Barf*  
24/4

*CPO (S2) M.Scell* FT 107  
*28/4*



1312 / CPO S2  
27/4 / 815

A G.T. letter is put for Signature please

*CPO (S2)*  
M.Scell  
*4/5*

*Sharma*  
28/4/18