

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI



No. F-6/DFS/Business/2018/MS/WZ/1061

Dated: 15/05/18

FIRE SAFETY CERTIFICATE

Certified that the **DC (West) Office** located at **Plot No. 3, Shivaji Place, Raja Garden, New Delhi - 110027** comprised of Two Basement + Ground + 5 Upper Floors owned/ occupied by **DC (West)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 04-05-2018 in the presence of Sh. SS Meena (AE Civil) and found that the said building that the premises is fit for occupancy class "**Business Building**" Group "**E**" with effect from 15/05/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on15/05/18... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service.


Copy to:

1. Deputy Commissioner (West), Old Middle School Building, Rampura, Delhi – 110035.
2. AE (Elec.), Sub Division West – 13, CTI Building, Raja Garden, New Delhi – 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per BBL 1983.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: DC (West) Office Located at plot no. 3, Shivaji Place, Raja Garden New Delhi
2. Type of Occupancy : Business Building” (B-1+B-2 + Ground + 5 Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F-6/DFS/MS/BP/2014/212 Dated 30/07/2014
6. Date of inspection : 01/05/2018
7. Name of the Inspecting Officer : DO/W & ADO (WP)
8. Name and designation of Officer
from the building side : Sh SS Meena (AE Civil)
9. Year of Construction : 2016-17
10. Applicant’s letter No. : 23(10)/AEPWD West (E)/SD-13/2017-2018/228 Dated-09/04/18

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	06 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	3	Provided	MR
	b. Width of staircases			
	• Upper floors	2x1.5 m	2X160cm	MR
	• Basements	3x1.5m & Ramp	3x164cm & 510cm & 560cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	1.5m	provided	MR
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	110 nos.	Provided	MR
	• Types	ABC & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of	20		

7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Each Floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	At strategic point	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 lpm	2850 lpm Provided	MR
	➤ Head of main pump	88 m	Provided	MR
	➤ Number of main pumps	02	Provided	MR
	➤ Jockey pump out put	2x180 lpm	Provided	MR
	➤ Jockey pump head	88 m	Provided	MR
	➤ Standby Pump out put	2280 lpm	2850lpm Provided	MR
	➤ Standby Pump Head	88m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	75,000 litres	1 lac ltrs Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 lpm	2850 lpm Provided	MR
	➤ Head of main pump	88 m	Provided	MR
	➤ Number of main pumps	02	Provided	MR
	➤ Jockey pump out put	2x180 lpm	Provided	MR
	➤ Jockey pump head	88 m	Provided	MR
	➤ Standby Pump out put	2280 lpm	2850lpm Provided	MR
	➤ Standby Pump Head	88m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	75,000 litres	1 lac ltrs Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR

111812

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

..... Nil

~~Signature of the Inspecting Officer~~

Signature of the Inspecting Officer

Name Uday Vir Singh

Name Sh Mohesh Verma

Designation ADO/W

Designation DO/W

~~Dr. Chandan~~
~~Chowdhary~~
 10/5/18
 FFB

~~DO/W~~
 F.T./FSC is put up for signature please.

~~Chowdhary~~
 15/5/18

15/5/18

M