

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/2018/ W2/1031

Dated: 11/5/18

**FIRE SAFETY CERTIFICATE**

Certified that the K.D. Model Sec. School (ID-65368) located at Bawana Road, Barwala, Delhi-110039 running on Ground Floor & 1<sup>st</sup> Floor only in a building comprising Ground + Two Upper Floors Only owned / occupied by K.D. Model Sec. School has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2015/WZ/262 dated 26/02/2015. The premises was re-inspected by the officer concerned of Fire Service on 01.05.2018 in the presence of Mr. Mudun Ansari and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Director of Education Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class Educational (For Ground Floor & 1<sup>st</sup> Floor only) with effect from 11/5/2018 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 11/5/18 at New Delhi by.

  
(ATUL GARG)  
CHIEF FIRE OFFICER.

**Copy to :-**

1. The Principal, K.D. Model Sec. School (ID-65368) located at Bawana Road, Barwala, Delhi-39.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

## INSPECTION REPORT

(Building comprised of Ground + Two Upper Floors, 2<sup>nd</sup> Floor is Blocked with Brick Wall)

1. Name & address of the building: **K.D. Model Sec. School (ID-65368),  
Bawana Road, Barwala, Delhi-110039.**
2. Type of Occupancy : Educational
3. Type of Case : Renewal (For Ground + One Upper Floor)
4. Details of previous NOC : F6/DFS/MS/School/2015/WZ/262 dated 26/02/2015
5. Fire Safety directives Letter No. : DOE Cir. Dated 01/03/2011
6. Date of inspection : 01/05/2018
7. Name of the Inspecting Officer : A.D.O. (Jwala Puri)
8. Name and designation of Officer  
from the building side : Mr. Mudun Ansari (Chowkidar)
9. Year of Construction : 1993
10. Applicant's letter No. : KDMS/Fire Safety/2018 dated 03/03/2018

Plot Area-256m <sup>2</sup>
Covered Area—1170.07m <sup>2</sup>

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir. Dated 01/03/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	3	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 Mtr & 1.35 mtr	1.10 Mtr x 1 1.00 mtr (Iron Metal) 1.50 Mtr x 1	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	---	---	---
	f. Door Size	1.00 Mtr.	1.10 Mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A

*(Handwritten Signature)*

5.	Fire Extinguishers			
	• Total numbers	5	11	MR
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	MR
	• IS marking	Required	Provided	M/R
6.	First – Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Not Provided	NMR
	➤ Head of the pump	40 MH	Not Provided	NMR
	➤ Power supply	Required	Not Provided	NMR
			Not Provided	NMR

14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	N/A	N/A	N/A
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route .....:- Clear
2. LPG cylinders in laboratories :- Nil
3. Electric wiring .....:- Conduit Wiring MCB and ELCB.....  
Electric circuit .....:- MCB Provided
4. Electric meter board / switch board panel.:-Not Under the staircase
5. Basement use as per BBL 1983 :- N/A
6. Emergency telephone no. board :- Displayed
7. Generator set ..... :- at the terrace

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2015/WZ/262 dated 26/02/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Dy CFO (WZ)

CFO West  
31/5/18

31/5/18

Ashok  
2/5/18

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (Jwala Puri)