

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**



No. F6/DFS/MS/SCHOOL/WZ/2018/ 999

Dated: 10/5/18

**FIRE SAFETY CERTIFICATE**

Certified that the Presidium School C/o Preeti Educational Society located at CS/OCE, Sector-5, Rohini, Delhi, comprised of Ground + Two upper floors only owned / occupied by Preeti Education Society, have complied with the fire prevention and fire safety requirements in accordance with NBC (Part-IV) / Director of Education Circular dated 01/03/2011 and verified by the officer concerned of Fire Service on 20.04.2018 in presence of Mrs. Vanita Gandhi (Principal) and that the building / premises is fit for occupancy class Educational (Group-B) with effect from ....10/5/18.....for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 10/5/18 at New Delhi by.

  
(ATUL GARG)  
CHIEF FIRE OFFICER.  


Copy to :-

1. Authorized Signatory, Presidium School C/o Preeti Educational Society, CS/OCE, Sector-5, Rohini, Delhi-110085.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
7. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

# INSPECTION REPORT

**Ground + Two upper Floors**  
**Total Student-100, Total Class Rooms-18**

1. Name & address of the building: Presidium School C/o Preeti Educational Society, CS/OCE, Sector-5, Rohini, Delhi-85.
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : NBC (Part-IV) / DOE Cir. 01/03/2011
6. Date of inspection : 20/04/2018
7. Name of the Inspecting Officer : A. K. Jaiswal
8. Name and designation of Officer from the building side : Mrs. Vanita Gandhi (Principal)
9. Year of Construction : 2007
10. Applicant's letter No. : - NIL Dated 09/03/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mtr.	6 Mtr.	MR
	• Gate width	4.5 Mtr.	4.5 Mtr.	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 x 1, 1.00 x 1	1.50 mtr x 1, 0.90 mtr to 1.00 mtr (Iron Metal)	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	---	1.40 mtr	MR
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	10	16	M/R
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	M/R
	• IS marking	Required	Provided	M/R

*(Signature)*



6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 mtr	30Mtr.	M/R
	• Nozzle diameter	5 mm	5mm.	M/R
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM x 2	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	M/R
	➤ Auto starting of pump	Required	Provided	M/R
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A



		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-A) **There is room on terrace for Kitchen / Toilet.**

B) General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route .....Clear.....
2. LPG cylinders in laboratories .....Nil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB .....
4. Electric meter board .....Not under the staircase.....
5. Basement use as per BBL 1983 .....NA.....
6. Emergency telephone no. board .....Displayed.....
7. Generator set .....Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

D/CFO (W2)  
 CFO. well  
 9/05/17  
 Add SP  
 FT P/L  
 25/18

  
 24.4.18

Signature of the Inspecting Officer  
 Name : Ashok Kumar Jaiswal  
 Designation : A.D.O. (Jwala Puri)

FT. is put up for signature please