

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/SZ/2018/ 1720

Dated: 24/07/2018

FIRE SAFETY CERTIFICATE

Certified that M/s **Ego Thai Restaurant** (A Unit of Bina Fashions N Food Pvt. Ltd) located at 52-53, Community Centre, New Friends Colony, New Delhi, comprised of basement (storage), Ground and mezzanine floor was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2015/SZ/1080 dated 25/06/2015. The restaurant was re-inspected by the officer concerned of this department on 09/07/2018 in the presence of Mr. Saurabh Khurana (GM) of the restaurant and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "**Assembly, Group-D**" (Restaurant) with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 24/07/2018 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Tel: 011-23412225

Copy to: -

1. M/s Ego Thai Restt at 52-53, Community Centre, New Friends Colony, N. Delhi-110065
2. DHO, South MCD, Public Health Department, Central Zone, Lajpat Nagar, New Delhi-24

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per BBL-1983 only.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT


S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Name & Address of the Building	M/s Ego Thai Restt at 52-53, Community Centre, New Friends Colony, New Delhi-110065 (A Unit of Bina Fashions N Food Pvt. Ltd)		
2	Type of Occupancy	Assembly, "Group-D" (Eating House)		
3	Building Comprised of	Basement, Ground, Mezzanine plus three upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2015/SZ/1080 dated 25/06/2015		
6	Fire Safety Directives Letter No	No. 4/22/2004/HP-III/356-359 dated 22-03-2005		
7	Date of Inspection	09-07-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Saurabh Khurana (GM)		
10	Year of construction	2006-07	Restt located at ground & mezzanine floor.	
11	Applicant letter No.	Outdoor Diary No. 7842 dated 25.05.2018		
1	Access to Building.			
	• Road width	Required	06 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	02 Nos	MR
	➤ Basement floor.	02 Nos	02 Nos	MR
	b) Width of Staircase			
	➤ Upper floors	1.25 mtr	1.08m & 1.04m	MR (old case)
	➤ Basement floor	1.25 mtr	1.08m & 1.04m	MR (old case)
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	Required	Gd. floor- 03 exits & Mezz. floor- 02 exits	MR (old case)
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors / Restt. area	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	11 Nos	MR
	• Types	ABC / CO2	ABC, CO2 & Foam	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

M/s Ego Thai Restt at 52-53, Community Centre, New Friends Colony, New Delhi

19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	ABC type fire extinguishers provided near electrical panel	-NA-


The fire protection system provided in the building/ premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/2015/SZ/1080 dated 25/06/2015, renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.



 Signature of the Inspecting Officer
 Name: Mehmood
 Design: ADO (SJ)

M/s Ego Thai Restt at 52-53, Community Centre, New Friends Colony, New Delhi

DO (SD)


13/7/18


CFO (S2)


13/7


CFO (S2)

M.Scell

F101.


W
20/7.

A. S.T letter being up for Signature please


CFO (S2)

M.Scell

W
24/7.


20/7/18



1647 CFO (S2)
20/7/18

1661 CFO (S2)
24/7/18