

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO.F6/DFS/MS/School/2018/SZ/ 1739

Dated: 25/7/18

FIRE SAFETY CERTIFICATE

Certified that the Delhi International School, located at Sector-18, Phase-II, Dwarka, New Delhi comprised of ground plus three upper floors owned/occupied by Great Harsh Educational Welfare & Charitable Society was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2015/SZ/723 dated 11.05.2015. The said school building was re-inspected by the officer concerned of this department on 28.06.2018 in presence of Sh.Sunil Chadda (Admin.) and found that the premises have deemed complied with fire prevention & fire safety requirements in accordance with rule 33 of the Delhi fire Service Act 2007 & Rules 2010 and that the premises/building is fit for occupancy class B "Educational building" with effect from...25/7/18... for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on25/7/18..... at New Delhi by


25/7/18
Vipin Kental
Chief Fire Officer


Copy to:-

1. The Dy. Director, (Education), G.N.C.T of Delhi, Old Secretariat, New Delhi-110054.
2. Principle, Delhi International School Sector-18, Phase-II, Dwarka, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

ADU Dunder

INSPECTION REPORT

1	Name & address of the building	Delhi international School (Great Harsh Educational welfare & Cheritable Society) Sector-18, Dwarka Phase-II, New Delhi		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (Ground Plus Three upper Floors)		
4	Details of previous NOC	F6/DFS/MS/School/2015/SZ/725 dated 11.05.2015		
5	Fire safety directives letter No	DOE Circular No. F-16/Estate/Fire Safety/2011/3298-3398 dated 1.3.2011/ NBC Part-IV of India		
6	Date of inspection	13.07.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Sunil Chadda (Admin.)		
9	Year of construction	2,015		
10	Applicant's letter No.	Nil dated 02.07.2018	Ground plus three upper floors.	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DIE Cir. Dated 1.3.2011 letter dated 11.05.2015	Provided at site	Remarks MR / NMR
--------	---	---	------------------	------------------

1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	4 Nos.	4 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	3 Nos. 1.5 & 1 No. 2.17 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	3 Nos.	3 Nos.	MR
	e. Width of corridor	1.5 Mtrs.	2.1 Mtrs.	MR
	f. Door size	1 Mtr.	Provided	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	N/A 12 a/c charge per hour	N/A	N/A
	upper floors		Natural Vent.	MR

5	Fire Extinguishers			
	total numbers	17 Nos. CO2 & ABC ISI Marked	18 Nos.	MR
	Types		ABC	MR
	ISI marking		Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	3 Nos.	4 Nos.	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	100 mm	MR
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM	MR
	b. head of the pump	35 Mtrs.	Provided	MR
	c. Power supply	Required	DG Set	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	10000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

419

17	Standby power supply	Required	DG Set	MR
18	Refuge Area.	Not Required		
	Total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire extinguisher provided near electric Panel.			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirement under the rules, renewal of fire safety certificate issued vide letter no. F6/DFS/MS/School/2015/SZ/725 dated 11.05.2015 is recommended.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
14/7/18
S.P. Bhardwaj
ADO (Dwarka)

~~DO/SW~~

[Signature]
16/7/18

~~DCFO(SZ)~~

835/DO/SW
16/7/18

[Signature]
15/7



[Signature]
CFO SZ

M-S/CELL
FT/MT
16/7

FT is put up for signature pl

1670/CFO SZ
25/7

[Signature]
CFO SZ

[Signature]
24/7/18

M-SCell
16/7