

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/G/SZ/2018/ 1768

Dated: 30/7/18

**FIRE SAFETY CERTIFICATE**

Certified that the **Evergreen Sweet House** situated at **Plot No. Y-48, Okhla Industrial Area Phase-II, New Delhi-110020** comprises of Basement, Stilt, Ground floor and Two Upper floor was granted FSC by this department vide letter No F6/DFS/MS/IND./2014/SZ/1637 dated 23/12/2014. The premises was re-inspected by the officer concerned of this department on 18/07/2018 in the presence of Sh. Parmod Kumar Sharma (Manager) and found that the said building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Group-G "Industrial"**" with effect from 30/7/2018 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....30/7/18.....at New Delhi by.

  
30/7  
(Vipin Kental)  
Chief Fire Officer  
Tel: 011-23412225

Copy to:-

1. The Executive Engineer (Bldg.), SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024
2. Sh. Parmod Kumar Sharma (Manager), Evergreen Sweet House, S-29-30, Green Park Market, New Delhi-110016

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doiit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

### INSPECTION REPORT

1. Name & address of the building: Evergreen Sweet House, Plot No. Y-48, Okhla Industrial Area Phase-II, New Delhi-110020
2. Type of Occupancy : Industrial "Group-G"
3. Type of Case : Renewal [Basement, Stilt, Ground & 2 Upper Floors]
4. Details of Previous NOC : F6/DFS/MS/IND./2014/SZ/1637 dated 23/12/2014
5. Fire Safety directives letter No : F6/DFS/MS/BP/2013/104 dated 03/06/2013
6. Date of inspection : 18/07/2018
7. Name of Inspecting Officer : A. K. Malik
8. Name and designation of officer from the building side : Mr. Parmod Kumar Sharma (Manager)
9. Year of Construction : 2014
10. Applicant's letter No. : Outdoor diary no. dated 16/07/2018 (C/14)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	12m 4.5m -NA-	Provided Provided -NA-	MR MR -NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	2 Nos 2 Nos	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.5m 1.5m	Provided Provided	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required -NA-	Provided -NA-	MR -NA-
	d. No. of continuous staircases to terrace	2 Nos	Provided	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1m	1m (final exit)	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required Required -NA- -NA- -NA-	Provided Provided -NA- -NA- -NA-	MR MR -NA- -NA- -NA-
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 ACPH 12 ACPH	M. V. Provided Ex. Fan Provided	MR MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	Required ABC/W.CO <sub>2</sub> / CO <sub>2</sub> Required	20 Nos 10/10 Nos Provided	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01 Nos 30m 5mm	Provided Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	Required Required -NA- Required Required	Smoke/Heat Ground Floor -NA- Provided All Levels	MR MR -NA- MR MR
8.	<b>MOEFA</b>			
		Required	Provided	MR
9.	<b>Public Address System</b>			
		Required	Provided	MR

10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	01 Nos	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01 Nos	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	02 Nos	Provided	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	02 Nos	Provided	MR
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	2280 LPM	Provided	MR
		60m	Provided	MR
		01	Provided	MR
		180 LPM	Provided	MR
		60m	Provided	MR
		2280 LPM	Provided	MR
		60m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		900 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	1,00,000 Lts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Lts	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	Required	Extinguisher Provided near electric panel	MR

-N/12-

Evergreen Sweet House, Plot No. Y-48, Okhla Industrial Area Phase-II, New Delhi-110020

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. The shortcomings recorded on file during the previous inspection dated 09/07/2018 found complied. Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 37(2) of the Delhi Fire Service Rules 2010.

Accordingly DFA of Form "H" is put up for approval under rule 37(3).

*A. K. Malik*  
18/7/18

Signature of Inspecting Officer  
Name: A. K. Malik  
Designation: Divisional Officer

DY. CFO(SZ)



*copy*  
*A*

*CFO (SZ)*

*M-sell*

*FT/10.*

*Ue*  
*30/7.*

*Sir f.c. is put up for Sr's pleasy.*

*CFO SZ*

*A. K. Malik*  
*30/7/18*

*DOL 800*

*M-sell.* *Ue*  
*30/7.*