

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2018 / W2 / 1754

Dated: 27 / 7 / 2018

FIRE SAFETY CERTIFICATE

Certified that the **Ganesh Diagnostic & Imaging Centre Pvt. Ltd** located at **Pocket CS/ OCF-7, Sector-08, Rohini, Delhi-110085** comprised of **Basement, Ground and 02 Upper floor** owned/ occupied by **M/s Ganesh Diagnostic & Imaging Centre Pvt. Ltd** was issued FSC vide this office letter no **F.6/DFS/MS/09/168** dated **20/01/2009**. The premise was re- inspected by the officer concerned of this department on 12.07.2018 in the presence of **Dr. Ravin Sharma** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premise have therefore, deemed complied with the requirement under rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy class "**Group C**" **Institutional for basement, ground and 02 upper floors** with effect from **27/7/18**..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.
8. The basement is not allowed to use as undertaking given by the Management.

Issued on **27/7/18**..... at New Delhi


(Atul Gang)
Chief Fire Officer
Ph:-011-23414250

Copy to :

1. M/s Ganesh Diagnostic & Imaging Centre Pvt. Ltd, Pocket CS/OCF-7, Sec-08, Rohini, Delhi-110085.

INSPECTION REPORT

1. Name & address of the building : Ganesh Diagnostic & Imaging Centre Pvt. Ltd, Pocket-CS/OCF-7, Sec-08, Rohini, Delhi-110085.
2. Type of Occupancy : Institutional (Basement+G+02 upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/09/168 dated 20.01.2009
5. Fire Safety directives letter No : F6/DFS/MS/2006/BP/2001 dated 10.08.2006
6. Date of inspection : 12.07.2018
7. Name of the Inspecting Officers : Rajesh Kumar /ADO (RN)
8. Name and designation of officers from the building side : Dr. Ravin Sharma
9. Year of Construction : --
10. Applicant's letter No. : Nil Dairy No 7753 dated 23.05.2018

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9m	13.5m	MR
	• Gate width	4.5m	4.5m	MR(old case)
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	2.0m & 1.50m	2.0m & 1.50m	MR
	• Basements	2.0m & 1.50m	2.0m & 1.50m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2m	2m	MR
3	Compartmentation.			

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required in basement	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30ACPH	Exhaust Fan	MR
	<ul style="list-style-type: none"> • Upper floors 	12ACPH	Natural	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10nos	12nos	MR
	<ul style="list-style-type: none"> • Types 	ABC/ Co2	ABC-12	MR
	<ul style="list-style-type: none"> • IS marking 	Required	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01nos	01nos	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	30m	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	G.F	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8	MOEFA			
		Required	Provided	MR
9	Public Address System.			
		Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			

	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01 nos each	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01nos each	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main Pump 	1620 lpm	1620 lpm	MR
	<ul style="list-style-type: none"> Head of Main pump 	70m	70m	MR
	<ul style="list-style-type: none"> Number of main pumps 	01	01	MR
	<ul style="list-style-type: none"> Jockey Pump out put 	180 lpm	180 lpm	MR
	<ul style="list-style-type: none"> Jockey pump head 	70m	70m	MR
	<ul style="list-style-type: none"> Standby Pump out put 	1620 lpm	1620 lpm	MR
	<ul style="list-style-type: none"> Standby Pump Head 	NA	NA	NA
	<ul style="list-style-type: none"> Auto Starting/ Manual 	Required	Provided	MR
	<ul style="list-style-type: none"> stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> Pump House Access 			
	<ul style="list-style-type: none"> Terrace level 	NA	NA	NA
	<ul style="list-style-type: none"> Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> Power Supply 	NA	NA	NA
	<ul style="list-style-type: none"> Auto Starting of pump 	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	50,000ltrs	50,000ltrs	MR
	<ul style="list-style-type: none"> Draw-off connection 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltrs	10,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication In lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> • Lift Signage 	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found in working conditions at the time of inspection

Keeping in view of the satisfactory compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to issue FSC under Rule 35 of Delhi Fire Service Rules, 2010.

Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation:- ADO/RN

Dy Insp 2
25/7/17
CFE-west
25/7/17
RPY

As approved, f.t. letter is put up for your signature pl
1/11/2017