

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/INDL/NDZ/2018/ 1811

Dated: 3/8/18

FIRE SAFETY CERTIFICATE

Certified that the M/s B.N. Enterprises at 203 FIE Patparganj, New Delhi - 110092, comprised of basement, ground, plus one upper floor, owned/occupied by M/s B.N. Enterprises, was granted FSC by this department vide letter No.F6/DFS/MS/2015/NDZ/592 dated 23.04.2015. The Premises was re-inspected by the officer concerned of this department on 27.07.18 in the presence of Sh. Ramesh Somani (Sr. Manager) and found that the Industrial building have deemed complied with the Fire prevention and Fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and found that the building comprised basement, ground plus one upper floor is fit for occupancy class industrial building Group (G) with effect from 3/8/18... for a period of three years in accordance with Rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on 3/8/18 at New Delhi by

4/2/18
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Senior Manager,
B.N. Enterprises
203 FIE Patparganj,
New Delhi -110092
2. The Commissioner
East Delhi Municipal Co-corporation
419, FIE, Patparganj. New Delhi.
3. The Chief Inspector of Factories,
D-Block, IInd Floor,
5 -Shyamnath Marg, Delhi-110054.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : B.N. Enterprises, 203 FIE Patparganj, New Delhi-110092.
2. Building is comprised of : BS+G+ 1 upper Floors.
3. Type of Occupancy : Industrial (G)
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/2015/NDZ/592 dt. 23/04/15
6. Fire Safety direction letter No : Existing Requirement
7. Date of Inspection : 27/07/2018
8. Name of the Inspecting officers : DO Francis Brown , ADO Omparkash
9. Name and designation of Officer from the building side : Sh. Ramesh Somani (Sr. Manager)
10. Year of Construction : 2004
11. Applicant's letter No : NIL Dated - 11/07/18

NO.	Minimum Standards on fire prevention and fire safety U/R33	Existing Requirement	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	09 Mtrs	13.5Mtrs	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 no.	03 no.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.25 m	1.50 m & 1.25 m 0.80 m	MR
	• Basement	1.25 m	1.50 m & 1.25 m	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Exhaust Fan	Exhaust Fan	MR
	• Upper floor	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	06 nos.	12 nos.	MR
	• types	ABC & Co2	Co2 not Provided	MR
	• ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 nos.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
		N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power			
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose Box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	900 LPM	MR
	➤ Head of Main Pump	N/A	40 M	MR
	➤ Number of main pumps	N/A	01 nos.	MR
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	Auto	MR
	➤ Pump House Access	N/A	Accessible	MR
	• Terrace Level			
	➤ Discharge of pump	450 LPM	900 LPM	MR
	➤ Head of the Pump	38 m	38 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	25,000 Liters	25,000 Liters	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Accessible	Accessible	MR
	• Overhead Tank capacity	15000 Liters	15000 Liters	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection system provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the NOC issued vide letter no. F6/DFS/MS/2015/NDZ/592 dt. 23/04/15 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended to renew fire safety certificate.

Ombakar 22/7/18

Signature of the Inspecting Officer
Name: Om Prakash
Designation: ADO (Shahdara)

[Signature]

Signature of the Inspecting Officer
Name: Francis Brown
Designation: DO (East)

DCFO(NDZ)

*CFD - M. SELL FTD
W 31/7*

*654 cad no 2
22/7/18/318*

FT label in process and put up for 8/5/18

CFD/MR M. SELL W 31/7

*[Signature]
218*