

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2018/NDZ/ 1808

Dated: 3/8/18

FIRE SAFETY CERTIFICATE

Certified that the **D.A.V. Public School, Sreshtha Vihar, Delhi-92**, owned/occupied by D.A.V. Public School, Comprised of basement, ground plus three upper floors was granted FSC vide letter **F6/MS/DFS/School/2015/NDZ/1034 dated-18/06/15**.The school building was re-inspected by the officer concerned of this department on 14/06/18 & 08/07/18 in the presence of **Smt. Premlata Garg (Principal)** of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 35 of the Delhi Fire Service rules 2010 and found that the building is fit for occupancy class B "Educational Building" with effect from **3/8/18**..... for a period of **three** years, subject to conditions printed overleaf.

Issued on**3/8/18**..... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,

The Principal,
D.A.V. Public School,
Sreshtha Vihar, Delhi-92.

Copy to:-

1. The Joint Director of Education,(Land & Estate)
Directorate of Education, Lucknow Road, Delhi-54.

Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. "The owner /occupier shall apply for renewal of this Fire Safety certificate to the Director inform'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : D.A.V. Public School, Sreshtha Vihar, Delhi-92.
2. Building is comprised of : Basement, ground+three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/MS/DFS/School/2015/NDZ/1034 dt-18/06/15
6. Fire Safety Circular No. : DFS Act 2007 & Rules 2010 | NBC-IV,
7. Date of Inspection : 14/06/18 & 08/07/18
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of
Officer from the building side : Smt. Premlata Garg (Principal)
10. Year of Construction : 1989
11. Applicant's letter No : Dated 30/08/16

S N	Minimum Standards on fire prevention and fire safety U/R33	Requirement NBC-IV	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 M	10 M	MR
		4.5 M	06 M	MR
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	05 No.	05 Nos.	MR
		02 Nos.	02 Nos.	MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor 	1.5 M	1.5 M, 1.5M, 1.5 M 1.25 M, 1.10 M	MR
	<ul style="list-style-type: none"> • Basement 	1.5 M	1.70 M & 1.20 M	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	2 Nos	2 Nos	MR
	g. Width of Corridor	1.5 M	2.4 M	MR
	h. Door Size	1.0 M	1.0 M	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	30a/c per hour	Exhaust fan	MR
		12a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types 	55 Nos.	55 Nos.	MR
		ABC & Co2	ABC & Co2	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	3 Nos	Provided	MR
	• Length of hose reel hose	30 M	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	3 No.	Provided	MR
	• Hose Box	3 No.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	2X450 LPM	Provided	MR
	➤ Head of the Pump	40M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15000Ltrs	Provided	MR
15	Exit Signage.			
		Required	Provided	MR

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC issued vide letter no. F6/MS/DFS/School/2015/NDZ/1034 dated-18/06/15 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

R. K. Yadav
 Signature of the Inspecting Officer
 Name: R. K. Yadav
 Designation: ADO(LN)

~~DO(ED)~~ *for*
16/7/18

~~DYCP/NDZ~~ *[Signature]*

G.F.P.
M'scell *FTM*
20/7

Sir, FT letter is put up for signature pl

~~CFD(LND 2)~~

[Signature]
24/7/2018

657/CFD/NDZ
30/7/18

M'scell *20/7*