

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/G/SZ/2018/ 1800

Dated: 1/8/18

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s Idea Cellular Limited** situated at **A-26/5, MCIE, Mathura Road, New Delhi-110044** comprises of Basement, Ground floor and One Upper floor was granted FSC by this department vide letter No. F6/MS/DFS/2002/114 dated 15/01/2002. The premises was re-inspected by the officer concerned of this department on 05/07/2018 in the presence of Mr. Bablu (Technical Supervisor) and found that the said building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Group-G "Industrial"**" with effect from 1/8/ 2018 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....1/8/18.....at New Delhi by.

30/7.  
**(Vipin Kental)**  
**Chief Fire Officer**  
**Tel: 011-23412225**

Copy to:-

1. The Executive Engineer (Bldg.), SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024
2. Sh. Surender Bamal (AGM-Network), M/s Idea Cellular Limited, A-26/5, MCIE, Mathura Road, New Delhi-110044

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

### INSPECTION REPORT

1. Name & address of the building: Idea Cellular Limited, A-26/5, MCIE, Mathura Road, New Delhi-110044
2. Type of Occupancy : Industrial "Group-G"
3. Type of Case : Renewal [Basement, Ground & 1<sup>st</sup> Floor]
4. Details of Previous NOC : F6/MS/DFS/2002/114 dated 15/01/2002
5. Fire Safety directives letter No : F6/DFS/MS/BP/98/1155 dated 22/06/1998
6. Date of inspection : 05/07/2018
7. Name of Inspecting Officer : A. K. Malik
8. Name and designation of officer from the building side : Mr. Bablu (Technical Supervisor)
9. Year of Construction : 2002
10. Applicant's letter No. : Outdoor diary no. 9362 dated 07/06/2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement under Rule 35(6)	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Required Direct Access NA	Provided Provided NA	MR MR NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	2 Nos 2 Nos	Provided Provided	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	1.2m 1.2m	Provided Provided	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	Required in Basement NA	Provided NA	MR NA
	d. No. of continuous staircases to terrace	2 Nos	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	1m (final exit)	NA
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	Required in Basement NA NA NA NA	Provided NA NA NA NA	MR NA NA NA NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 ACPH 12 ACPH	Ex. Fan Provided Natural Ventilation	MR MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	08 No's ABC/W.CO <sub>2</sub> / CO <sub>2</sub> ISI marked	12 Nos 4/4/4 Nos Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 Nos 30m 5mm	Provided 30m 5mm	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA	Smoke/Heat Ground Floor NA Provided All Levels Provided	NA NA NA NA NA NA

9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floors</li> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	100mm	Provided	MR
		01 Nos	Provided	MR
		01 Nos	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA	03 Nos	NA
		NA	03 Nos	NA
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual Stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		960 & 360 LPM	Provided	MR
		56 & 46m respectively	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	25,000 Lts	Provided	MR
		NA	NA	NA
		NA	Provided	NA
		NA	NA	NA
		20,000 Lts	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	<b>Standby power supply</b>	NA	Provided	NA
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	<b>Special Fire Protection System for</b>	NA	NA	NA

A/12-

Idea Cellular Limited, A-26/5, MCIE, Mathura Road, New Delhi-110044

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. The shortcomings communicated vide letter no. F6/DFS/MS/Educational/SZ/2018/1272 dated 28/03/2018 found complied. Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 37(2) of the Delhi Fire Service Rules 2010.

Accordingly DFA of Form "H" is put up for approval under rule 37(3).

*[Signature]*  
6/7/18

Signature of Inspecting Officer  
Name: A. K. Malik  
Designation: Divisional Officer

DY/CFO(SZ)

*[Signature]*  
9/7

*[Signature]*

m-scell FID  
11/7

Shy F.T is put up for dis. please.



*[Signature]*  
13/7/18  
DOLSD

*[Signature]*

*[Signature]*  
29/7

*[Signature]*

m-scell  
30/7

1673/Ch-82  
4/8/18