

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/GH/SZ/2018/ 1820

Dated: 6/8/18

FIRE SAFETY CERTIFICATE

Certified that M/s. La Suite Hotel located at E-2/14, East Patel Nagar, New Delhi-110008 comprised of basement, ground plus two upper floors, using basement as hall/storage, ground floor as reception, office, lobby, pantry & 04 guest rooms, first & second floor each having 08 guest rooms respectively (total 20 guest rooms) and a hall in temporary shed on terrace, was granted FSC by this department vide letter No. F6/DFS/MS/GH/2015/SZ/1070 dated 24.06.2015. The premises was re-inspected by the officer concerned of this department on 10.07.2018 in presence of Sh. Hitesh Gaur, manager of the guest house and found that deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) with effect from 6/8/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 6/8/18 at New Delhi by.

W. K. 30/7
(VIPEN KENTAL)
CHIEF FIRE OFFICER

Copy to:-

1. Sh. Tarun Pal Singh (owner), M/s. La Suite Hotel, E-2/14, East Patel Nagar, New Delhi- 08.
2. The Joint C.P. (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.

Following Fire Safety Directives must be adhered to: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s. La Suite Hotel, E-2/14, East Patel Nagar, New Delhi- 08.
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2015/SZ/1070 dated 24.06.2015
5. Fire Safety directives letter No : Nil
6. Date of inspection : 10.07.2018
7. Name of the Inspecting Officers : M.K. Chattopadhyay, DO(South West)
8. Name and designation of officers from the building side : Sh. Hitesh Gaur, manager
9. Year of Construction : Before 2007
10. Applicant's letter No. : 3807/Addl. C.P/Lic (H) dated New Delhi the 30.05.2018

The said guest house is comprised of basement, ground plus two upper floors .

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per letter dt. 24.06.2015	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5mts	Provided (05 mts)	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02	02	MR
	• Basements	01	01	MR being old case
	b. Width of staircases	-	-	-
	• Upper Floors	Old case	1.25, 0.90 mts	MR being old case
	• Basements	Old case	1.0 mt.	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	Old case	1.35 mts	MR
	h. Door Size	Old case	0.87 mts	MR being old case
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	Sealed	----
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour		

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	Provided	MR
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	Old Case	Provided (5000 lts)	MR being old case
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/GH/2015/SZ/1070 dated 24.06.2015, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.



[Handwritten Signature]
16/7/18

Signature of the Inspecting Officer
Name M.K. CHATTOPADHYAY
Div. Officer (South West)

DCFO (SZ)

746/00/SW
16/7/18

1663/CH/SZ
24/7/18

FTD.

m. scell

U