

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI-110001


No. F.6/DFS/MS/EH/SZ/2018/1819

Dated: 03/08/18

FIRE SAFETY CERTIFICATE

Certified that M/s **Smoke House Deli Restaurant** (A Unit of Impresario Entertainment & Hospitality Pvt. Ltd) located at Ground Floor, 9A, 12 & T-1A2, Main Hauz Khas Village, New Delhi-110016, comprised of Ground + 03 upper floors. The restaurant is running at ground floor only was issued FSC by this department vide letter No. F.6/MS/DFS/EH/2015/SZ/160 dated 03/02/2015. The restaurant premise was re-inspected by the officer concerned of this department on 29/06/2018 in the presence of Mr. Arun Rana (Manager) of the restaurant and found that the said restaurant premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "**Assembly, Group-D**" (Eating House) with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 03/08/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Tel: 011-23412225

Copy to: -

1. Auth. Signatory, M/s Smoke House Deli (A Unit of Impresario Entertainment & Hospitality Pvt. Ltd) at Ground floor, 9A, 12 & T-1A2, Hauz Khas Village, New Delhi-110016
2. The DHO (South Zone), South MCD, Aurobindo Marg, Green Park, New Delhi-110016

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	M/s Smoke House Deli Restaurant, Ground floor, 9-A, 12 & T-12A, Hauz Khas Village, New Delhi-16 (A Unit of Impresario Entertainment & Hospitality Pvt. Ltd.)		
2	Type of Occupancy	Assembly, "Group-D" (Eating House)		
3	Building Comprised of	Ground plus three floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2015/SZ/160 dated 05/02/2015		
6	Fire Safety Directives Letter No	F.6/DFS/MS/EH/2005/718 dated 04-04-2005		
7	Date of Inspection	29-06-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Arun Rana (Manager)		
10	Year of construction	1980   Restt is running at ground floor only		
11	Applicant letter No.	Outdoor Diary No. 7005 dated 07.06.2018		
S. No.	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>			
	• Road width	6 mtr	4.5m + 1.5m	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	-NA-	Restt. at GF only	-NA-
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	Required	One	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	02 exits	1.80, 1.18 & 1.09m	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors / Restt. area	12 ACPH	Provided in kitchen	MR
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	06 Nos	MR
	• Types	ABC / CO2	ABC, W.CO2 & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Two	MR
	• Length of hose-reel hose.	30m	30m each	MR
	• Nozzle Diameter	5mm	5mm each	MR

M/s Smoke House Deli Restt, GF, 9A, 12 & T-12A, Hauz Khas Village, New Delhi

7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	-NA-	Smoke type	-NA-
		-NA-	Ground floor	-NA-
		-NA-	-NA-	-NA-
		-NA-	Provided	-NA-
		-NA-	Provided	-NA-
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors.</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	Required	100mm	MR
		Required	One	MR
		Required	One	MR
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting / Manual Stopping.</li> <li>Pump house access.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>	450 LPM	450 LPM	MR
		40 mtr	40 mtr	MR
		One	One	MR
		180 LPM	180 LPM	MR
		40 mtr	40 mtr	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity. <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	10,000 Ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-


M/s Smoke House Deli Restt, GF, 9A, 12 & T-12A, Hauz Khas Village, New Delhi

19.	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

The fire protection system provided in the building/ premises were test checked at random and found functional at the time of inspection. The shortcomings communicated by this department vide letter dated F6/DFS/MS/EH/2018/SZ/962 dated 08/03/18 found complied

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F.6/MS/DFS/EH/2015/SZ/160 dated 03/02/15, renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name: Mehmoed  
 Design: ADO (SJ)

M/s Smoke House Deli Restt, GF, 9A, 12 & T-12A, Hauz Khas Village, New Delhi

~~DO (SD)~~

*fl speak on the requisitement of road width.*

*ADO  
5/5/18*

*Anilash  
10/1/18*

*Spoken with ADO/SS. on 31/7/2018, ADO/SS informed that another restaurant namely Social & Timur is recently renewed by Competant authority with same parameters of Access Road. The file of Social & Timur is called from PLW and enclosed. # May please see my remark at N/23 of enclosed file. The case was not recommended by undersigned. Further ADO/SCF at that time i.e Sh. Ramnivas also clarified on the same noting that the center of the footpath.*