

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/ School/WZ/2018/ 1879

Dated: 9 / 8 /2018

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-Ed. Sec. School (Code No.61280) located at Kunwar Singh Nagar, Ranhola, Delhi-41, comprised Two Blocks of Ground + One Upper floors only owned / occupied by Govt. Co-Ed. Sec. School, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2015/WZ/1288 dated 17/07/2015. The premises was re-inspected by the officer concerned of Fire Service on 27.07.2018 in the presence of Mr. Vishnu Gopal (Estate Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Director of Education Circular dated 01/03/2011 and that the building / premises is fit for occupancy class Educational with effect from 9 / 8 /2018 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 9/8/18 at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to :-

1. Head of School, Govt. Co-Ed. Sec. School, Kunwar Singh Nagar, Ranhola, Delhi -110041.
2. The Director of Education, Old Secretariat, Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
4. This certificate cannot be treated in any case for regularizations of unauthorized construction.
5. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
6. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

1. Name & address of the building: Govt. Co-Ed. Sec. School (Code-61280), Kunwar Singh Nagar, Ranhola, Delhi.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2015/WZ/1288 dated 17/07/2015
5. Fire Safety directives Letter No. : DOE Circular Dated 01/03/2011
6. Date of inspection : 27/07/2018
7. Name of the Inspecting Officer : A. K.-Jaiswal
8. Name and designation of Officer
from the building side : Mr. Vishnu Gopal (Estate Manager)
9. Year of Construction : 2013-14
10. Applicant's letter No. : - Nil Dated 16/07/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE. Circ. Dated 01/03/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	a) 2 in 1 st Block b) 4 in 2 nd Block	MR
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtr.	135cm X 2 & 145cm X 4	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	One in each block	Provided	MR
	e. Width Of Corridor	1.50 mtr.	1.50 mtr	MR
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	15	74	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R

6.	First - Aid Hose Reels			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank	N/A	N/A	N/A

15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape route Clear.....
2. LPG cylinders in laboratories Nil.....
3. Electric wiring ...Conduit Wiring..... MCB and ELCB
Electric circuit
4. Electric meter boardNot under the staircase.....
5. Basement use as per BBL 1983NA.....
6. Emergency telephone no. boardDisplayed.....
7. Generator setNil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2015/WZ/1288 dated 17/07/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O/ (crest)

Ashok Jaiswal
30/7/2018

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

Mukherjee
30/7/18

Dr. A.D.O. (WZ)

Ch. work

31/8/18