

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/Hospital/SZ/2018/ 1854

Dated: 08.08.2018

**FIRE SAFETY CERTIFICATE**

Certified that the **Max Super Specialty Hospital**, situated at Plot No. 1, Press Enclave Road, Saket, New Delhi-110017, comprised of 2 tier Basement, Ground and Six Upper Floors was granted FSC by this department vide letter no. F6/MS/DFS/Hospital/2015/SZ/288 dated 27/02/2015. The premise was re-inspected by the officer concerned of this department on 27/07/2018 in the presence of Mr. Kapil Dixit (Fire Officer) & found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy **Group C "Institutional (Hospital)"** with effect 08.08.2018 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on 08.08.2018 at New Delhi by.

  
(Vipin Kental)  
Chief Fire Officer  
Ph:-011-23412235

Copy to:-

1. Sh. Dharmender Kumar, Associate Director, Max Super Specialty Hospital, Plot No. 1, Press Enclave Road, Saket, New Delhi-110017.
2. Executive Engg. (Bldg.), SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."



**INSPECTION REPORT**

1. Name & address of the building : Max Super Specialty Hospital, Plot No.1, Press Enclave Road, Saket, New Delhi-110017.
2. Type of Occupancy : Institutional "Group-C"
3. Type of Case : Renewal [Two Tier Basement, Ground & Six Upper Floors]
4. Details of Previous NOC : F6/MS/DFS/Hospital/2015/SZ/288 dated 27/02/2015
5. Fire Safety directives letter No : F6/DFS/MS/BP/Hospital/2004/1986 dated 02/09/2004 & even no. 465 dated 23/02/2006
6. Date of inspection : 27/07/2018
7. Name of Inspecting Officer : A. K. Malik
8. Name and designation of officer from the building side : Mr. Kapil Dixit (Fire Officer)
9. Year of Construction : 2008-09
10. Applicant's letter No. : Outdoor diary no. 10229 dated 15/07/2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	9m 5m 6m	Provided Provided Provided	MR MR MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	4 Nos 4 Nos	Provided B2 to GF: 4 Nos B1 to GF: 2 Nos	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	2m 2m	Provided B2 to GF: 2 of 2m & 2 of 1.5m B1 to GF: Provided	MR MR(oid case)
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	Required Required	Provided Provided	MR MR
	d. No. of continuous staircases to terrace	Required	4 Nos	MR
	e. Width of Corridor	2m	Provided	MR
	f. Door Size	2m & 1m	1.7m & 1.05m	MR (oid case)
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	Required Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 ACPH 12 ACPH	M. V. Provided M. V. Provided	MR MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	ISI marked	280 Nos ABC/W. CO <sub>2</sub> /CO <sub>2</sub> - 100/100/80 Nos Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	4 Nos 30m 5mm	Provided Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> </ul>	Required Required	Smoke & Heat Decomment 1	MR MR



	<ul style="list-style-type: none"> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	Required	Provided	MR
		Required	All Area	MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	150mm	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	4 Nos	Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	4 Nos	Provided	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	7 No's	Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	7 No's	Provided	MR
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual Stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	2850 LPM	Provided	MR
		60m	Provided	MR
		Two	Provided	MR
		2 x 180 LPM	Provided	MR
		60m	Provided	MR
		2850 LPM	Provided	MR
		60m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>	2,00,000 Lts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Lts	Provided	MR
		Required	Provided	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> </ul>	Required	Compensated by Shaft pressurization (Table-6, NBC-2016)	MR
	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	Required	Provided	MR
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> </ul>	Required	130 m <sup>2</sup>	MR
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	6 <sup>th</sup> Floor	3 <sup>rd</sup> , 4 <sup>th</sup> , 5 <sup>th</sup> & 6 <sup>th</sup> Floors	MR (old case)
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	Required	Provided	MR



