

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZ/ 1876

Dated: 8/8/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Oriental Modern Public School, V-497, Shiv Mandir Marg , Arvind Nagar, Ghonda, Delhi - 110053, school is running on ground plus one upper floor of the building comprised of Ground plus two upper floors owned / occupied by Oriental Modern Public School was issued FSC vide letter No. F.6/DFS/MS/2007/866 Dated 23/03/2007. The school building was re-inspected by the officer concerned of this department on 25/06/18 in presence of Sh. Raja Ram Dhama, Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17/01/2005 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 8/8/18 for a period three year, subject to conditions printed overleaf.

Issued on 8/8/2018 at New Delhi by

u
3/8
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,
The Principal,
Oriental Modern Public School,
V-497, Shiv Mandir Marg , Arvind Nagar, Ghonda,
Delhi- 110053.

Copy to:-
The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi- 110053.

ok
h

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Oriental Modern Public School, V-497, Shiv Mandir Marg, Arvind Nagar, Ghonda, Delhi - 110053.
2. Building is comprised of : G+2 (School running at G+1)
3. Type of Occupancy : Educational
4. Type of Case : **Renewal**
5. Details of Previous FSC letter : F.6/DFS/MS/2007/866 Dated 23/03/2007
6. Fire Safety circular No : Circular 2005 issued by D.o.E.
7. Date of Inspection : 25/06/18
8. Name of the Inspecting officers : ADO Om Prakash
9. Name and designation of Officer from the building side : Sh. Raja Ram Dhama (Manager)
10. Year of Construction : 1998
11. Applicant's letter No : NIL Dated - 01/06/18

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement DOE	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	06 Mtrs	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 no.	02 no.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 m	1.0 m each	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01 no.	01 no.	MR
	g. Width of Corridor	1.5 m	6 m	MR
	h. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 nos.	06 nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	220 lpm	220 lpm	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 Ltrs.	2500 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules. It is recommended to renew Fire Safety Certificate.

Om Prakash
17/7/18

Signature of the Inspecting Officer
Name: Om Prakash
Designation: ADO

Submitted for approval plan 1

DO/East

AO/CAO
25/2
8/8,

DY/CAO/NDM
[Signature]

[Signature]
17/7/18

G. F. P. m.scell FT/DT
[Signature]

Ft. letter is prepared and put up for signat's plan

CAO/NDM m.scell *[Signature]*
3/8

[Signature]
25/7