

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/2018/NDZ/ School/ 1951

Dated: 23/8/18

**FIRE SAFETY CERTIFICATE**

Certified that the **B.M. Gange Girls Senior Secondary School** located at **21, Raj Niwas Marg, Delhi** comprises of **One Block - Ground + 01 Upper floor and Four Block Single Storey** owned/occupied by **B.M. Gange Girls Senior Secondary School** was granted NOC by this department vide letter No. **F6/DFS/MS/2008/57** dated **09/01/2008**. The premises was re-inspected by the officer concerned of this department on **04-08-2018** in the presence of **Sh. M.M. Philip (Principal)** and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with **Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398** dated **01/03/2011** issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. B-I** with effect from **23/8/18** 2018 for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on .....**23/8/18**..... at New Delhi by.

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Principal,  
B.M. Gange Girls Senior Secondary School at 21, Raj Niwas Marg, Delhi
2. The Joint Director of Education (land & Estat),  
Director of Education, Lucknow Road, Delhi.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

## INSPECTION REPORT

1. Name & address of the building:- B.M. Gange Girls Senior Secondary School  
at 21, Raj Niwas Marg, Delhi
2. Type of occupancy:- Educational Group B-I, Gr.+01 Upper Floor
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/DFS/MS/2008/57 dated 09/01/2008.
5. Fire safety directives No.- N/A
6. Date of inspection:- 04/08/18
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/CC)
8. Name & designation of officer  
From the building side:- Sh. M.M. Philip (Principal)
9. Year of construction:- Old
10. Applicant's letter No:- BMG/2018-19/77 dated 02/07/2018

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	20 mtr.	MR
	2) Gate width	NA	NA	NA
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 & 1.5 mtr.	1.25 & 1.5 mtr. each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	02	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	14 Nos.	18 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	N/A	N/A	N/A


*Handwritten signature*


6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	02	N/A
	2) Length of hose reel hose	N/A	30 mtr.	N/A
	3) Nozzle diameter	N/A	05 mm	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	220 LPM	N/A
	b) Head of pump	N/A	30 mtr.	N/A
	c) Power supply	N/A	Provided	N/A
	d) Auto starting of pump	N/A	Provided	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A

	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the Director Education Circular, the FSC issued vide letter No. F6/DFS/MS/2008/57 dated 09/01/2008, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer  
  
 Name :- M.K. Sharma  
 Designation :- A. D.O. (CC)

Dy. CFO/NDZ  


714/CFO/NDZ  
 14/8/24/8

M.P. m.scell

FT/101.  
 14/8

F.T. letter is put up for sign. pl  
