

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/School/2018/ ND2/1906

Dated: 16/8/18

FIRE SAFETY CERTIFICATE

Certified that M/s B.A.V. Model Public School running on ground floor only of the building comprised of ground plus one upper floor located at B-75, Gamri Road, Ghonda, Delhi110053, owned/occupied by B.A.V. Model Public School was inspected by the officer concerned of this department in the presence of Ch. Bhagmal Singh, Manager of the school and found that the school building have complied with the fire prevention and fire safety requirements in accordance with Circular Letter No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 16/8/18.....for a period of **three** years, subject to conditions, printed overleaf.

Issued on 16/8/18.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

To,  
The Principal,  
M/s B.A.V. Model Public School,  
B-75, Gamri Road, Ghonda,  
Delhi110053,

Copy:-  
The Director of Education, EDMC,  
Udyog Sadan, Plot No.419, FIE,  
Patparganj Industrial Area, Delhi-110092

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry



- M/1
1. Name & address of the building : B.A.V. Model Public School,  
B-75, Gamri Road, Ghonda, Delhi 110053
  2. Building is comprised of : Ground plus one upper floors  
(School is running on ground floor only, 1<sup>st</sup> floor residence of owner)
  3. Type of Occupancy : Educational
  4. Type of Case : New
  5. Details of Previous NOC letter : Nil
  6. Fire Safety direction letter No : F16/Estate/CC/FireSafety/2011/3298to3398 dt-01/03/11
  7. Date of Inspection : 28/07/2018
  8. Name of the Inspecting officers : ADO Vijay Bahadur
  9. Name and designation of Officer  
from the building side : Ch. Bhagmal Singh, Manager
  10. Year of Construction : 2015
  11. Applicant's letter No : Nil, Dated- 17/07/2018

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 mtr. N/A N/A	06 mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	N/A N/A	02 nos. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	N/A N/A	1.20 mtr each N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	N/A N/A	N/A N/A	N/A N/A



1/2

05.	Fire Extinguishers			
	• Total numbers	02 nos.	05 nos.	MR
	• Types	ABC /CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants:			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A




1/25

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A



The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by Director of Education, it is recommended to issue Fire Safety Certificate.

666/CR0/ND2  
10/8/18  
1688



Signature of the Inspecting Officer  
Name :- Vijay Bahadur  
Designation :- A.D.O (TP)

DO(ED)   
DYCRO/ND2 

CFD - miscell  
FTB  
16/8

Say FT letter is put up for signature