

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2018/ NDZ/ 1956

Dated: 27/8/18

FIRE SAFETY CERTIFICATE

Certified that M/s D.R.P. Convent Sec. School located at Babu Nagar, Shiv Vihar Tiraha, Delhi -110094, comprised of ground plus two upper floors only owned/occupied by D.R.P. Convent Sec. School was issued NOC vide letter No. F6/ DFS/MS/2010/2232 dated 28/07/10. The school building was re-inspected by the officer concerned of this department in the presence of Mr. Pankaj Sharma, Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No.262-362 Dated-17/01/05 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 27/8/18 for a period of **three** years, subject to conditions, printed overleaf.

Issued on 27/8/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

To,
The Manager,
M/s D.R.P. Convent Sec. School
Babu Nagar, Shiv Vihar Tiraha,
Delhi -110094

Copy:-
The Dy. Director of Education
B-Block, Yamuna Vihar,
Delhi-110053

o/c
h

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

- 21/8
1. Name & address of the building : D.R.P. Convent Sec. School School
Babu Nagar, Shiv Vihar Tiraha, Delhi -94
 2. Building is comprised of : Ground plus two upper floors
 3. Type of Occupancy : Educational
 4. Type of Case : **Renewal**
 5. Details of Previous NOC letter : F6/ DFS/MS/2010/2232 dated 28/07/10
 6. Fire Safety directive letter No. : Circular 262-362 dated 17/01/2005 issued by DoE
 7. Date of Inspection : 08/08/2018
 8. Name of the Inspecting officers : ADO Vijay Bahadur
 9. Name and designation of Officer from the building side : Mr. Pankaj Sharma, Manager
 10. Year of Construction : 1998 to 2006
 11. Applicant's letter No : DRP/SL/18 dated 26/07/2018

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr. N/A N/A	12 mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 nos.	02 nos.	MR
	<ul style="list-style-type: none"> • Upper floor • Basement 	N/A	N/A	N/A
	B. Width of Staircases	1.50 mtr	1.34 mtr & 0.78	MR
	<ul style="list-style-type: none"> • Upper floor • Basement 	N/A	N/A	N/A
	c. Protection of Exits	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	1.50 mtr.	2.57 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A N/A	N/A N/A	N/A N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI marking 	06 nos. ABC /CO ₂ ISI marked	06 nos ABC & CO ₂ Provided	MR MR MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 nos.	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose box <i>per floor</i>	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 lpm	450 lpm	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	5,000 ltr	5,000 ltr	MR
15	Exit Signage.	Required	Provided	MR

M/7

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply			
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the Circular 262-362 dated 17/01/2005 issued by DoE, it is recommended to issue Fire Safety Certificate.

Vijay Bahadur
21/8/18

Signature of the Inspecting Officer
Name :- Vijay Bahadur
Designation :- A.D.O (T.Pur)

~~DO(ED)~~ *[Signature]*
10/8/18
DY (FO) / NDm. *[Signature]*

C. F.P. M.Sc. FT M. W. 21/8

FT FSC is put up for signature please

CFD (NDZ)

M.Sc. W. 27/8

[Signature]
23/8/18