

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/WZ/2018/ 205

Dated: 31/08/2018

FIRE SAFETY CERTIFICATE

Certified that the B.S. International School at Plot No. 26, Dalip Vihar, Nilothi Extn., New Delhi-110041, comprised of Ground + Two Upper Floors only, owned / occupied by Shri Dalip Singh Educational & Welfare Society, A-50, Uday Vihar, Nilothi, Delhi-41, has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/WZ/2015/1278 dated 17/07/2015. The premises was re-inspected by the officer concerned of Fire Service on 20.08.2018 in the presence of Sh. Anoop Shokeen (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Directorate of Education, Circular No. 262-362 dated 17.01.2005 and that the building / premises is fit for occupancy class **Educational** (Group-B) with effect from 31/08/2018 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules,2010.

Issued on 31/08/18 at New Delhi by.

(ATUL GARG)
CHIEF FIRE OFFICER.

Copy to :-

1. Manager, B.S. International School, Plot No. 26, Dalip Vihar, Nilothi Extn., New Delhi-110041.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
7. There shall not be more than 45 students in class rooms in any case.

INSPECTION REPORT

N 9

1. Name & address of the building: **B.S. International School, Plot No. 26, Dalip Vihar, Nilothi Extn., New Delhi-110041.**
2. Type of Occupancy : Educational (G+2)
3. Type of Case : Renewal (Plot Area-1 Acre, Cov. Area-9000m²)
4. Details of previous NOC : **F6/DFS/MS/School/WZ/2015/1278 dated 17/07/2015**
5. Fire Safety directives Letter No. : Circular No. 262-362 dated 17.01.2005
6. Date of inspection : 20/08/2018
7. Name of the Inspecting Officer : A. K. Jaiswal
8. Name and designation of Officer
from the building side : Sh. Anoop Shokeen (Manager)
9. Year of Construction : 2009
10. Applicant's letter No. : Nil dated 04/08/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE. Circ. Dated 17/01/2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 mtr	1.50 mtr x 2	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.50 mtr	2.70 mtr	MR
	f. Door Size	1.00 mtr	1.10 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	6	6	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR

AKJ

N/A				
6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	NR	Provided	NR
	• Number of hydrants per floor	NR	NR	NR
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 Lit/Mint.	450 LPM x 2	MR
	➤ Head of the pump	40 Mtr. Head	40 Mtr. Head	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under Ground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	

		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-General requirements for schools as per Director of Education circular dated 17/01/2005.

1. Escape route Clear.....
2. LPG cylinders in laboratories Nil.....
3. Electric wiring ... Conduit Wiring..... MCB and ELCB
4. Electric meter board Not under the staircase.....
5. Basement use as per BBL 1983 NA.....
6. Emergency telephone no. board Displayed.....
7. Generator set Nil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/WZ/2015/1278 dated 17/07/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O. / (W)

[Handwritten signature]
24/8/18

[Handwritten signature]
21/08/18

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

[Handwritten signature]
29/08/18

[Handwritten signature]
29/8/18

[Handwritten signature]
29/08/18

[Handwritten signature]
29/08/18

for signature pl.