

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001



No. F6/DFS/MS/School/2018/NDZ/ 1978

Dated: 28/8/18

**FIRE SAFETY CERTIFICATE**

Certified that the **Bal Vikas Vidyalaya, Block-8, Trilok Puri, Delhi-92**, comprised of ground plus one upper floor owned/occupied by Bal Vikas Vidyalaya was granted FSC vide letter no. **F.6/DFS/MS/School/2016/NDZ/71 dated 08/01/16**. The school building have deem complied with the fire prevention and fire safety requirements in accordance with the Circular no.F16/Estate/CC/FS/2011/3298 to 3398 dated 01/03/11 issued by the Director of education and verified by the officer concerned of this department on 06/08/18 & 16/08/18 in the presence of **Sh. Surender Pal Verma (Manager)** of the school and found that the building is fit for occupancy class B ' Educational Building' for ground plus one upper floor only with effect from .....28/8/18. for a period of **three** years, subject to conditions printed overleaf.

Issued on.....28/8/18.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  


To,

The Manager,  
Bal Vikas Vidyalaya,  
Block -8, Trilok Puri, Delhi-92.

Copy to:-

1. Dy Director of Education,  
D-Block Anand Vihar, Delhi

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building: Bal Vikas Vidyalaya at Block -8, Trilok Puri, Delhi-92.
2. Building is comprised of : School running at A block (New) gr.+1 floor & B (old) g+2 block was closed.
3. Type of Occupancy : Educational
4. Type of Case : Renewal.
5. Details of Previous NOC letter : F.6/DFS/MS/School/2016/NDZ/71 dated 08/01/16
6. Fire Safety direction letter No : F16/Estate/CC/FS/2011/3298 to 3398 dated- 1.3.11
7. Date of Inspection : 06/08/18 & 16/08/18
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of Officer from the building side : Sh. Surender Pal Verma
10. Year of Construction : 2004
11. Applicant's letter No : Nil dated 02/07/18

NO.	Minimum Standards on fire prevention and fire safety U/R33	Old Circular Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 Mtrs.	09 Mtrs.	MR
	• Gate width	4.5 Mtrs.	5.0 Mtrs.	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	03 Nos	04 Nos	MR
		N/A	N/A	N/A
	• Basement			
	B. Width of Staircases	1.5 M	2 Nos. of 1 M. & 1 no. of 1.7 M & 1 no. of .80 m	MR
	• Upper Floor			
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	2 nos.	3 nos.	MR
	h. Door Size	1.5 M	1.5 M	MR
		1.0 M	1.0 M	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	06 no.	15 no.	MR
	• Types	ABC & CO2	ABC & CO2	MR
	• IS marking	ISI Marked	ISI Marked	MR

N/A

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	Provided	MR
	• Length of hose reel hose	N/A	30 m	MR
	• Nozzle diameter	N/A	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put			
	➤ Jockey pump head			
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	450 LPM provided	MR
	➤ Head of the Pump	N/A	40 M	MR
	➤ Power supply	N/A	Provided	MR
	➤ Auto Starting of pump	N/A	Manual	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	5000 Ltrs.	MR
15	Exit Signage.	N/A	N/A	N/A

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC was issued vide letter no. F.6/DFS/MS/School/2016/NDZ/71 dated 08/01/16 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

*R.K. Yadav*  
16/8/2018

Signature of the Inspecting Officer  
Name:-R.K.Yadav  
Designation:-ADO(LN)

DO(ED) *on leave*  
*DY CPO (ND2)*

*[Signature]*

*C.F.O. m.scell* *FTD.*  
*16/23/18*

*671/CFOND2*  
*23/8/18*

*Sdy FT Letter is put up for signature plz*

*R.K. Yadav*  
*28/8/2018*

*CFOND2* *m.scell* *16/28/18*