



No. F6/DFS/MS/EH/WZ/2018/ 2035

Dated: 5/9/18

**FIRE SAFETY CERTIFICATE**

Certified that M/s Masabaa The Treasury (a unit of VSR Foods India) at premises No. 37, 2<sup>nd</sup> & 3<sup>rd</sup> floor, Club Road Punjabi Bagh, New Delhi in a building comprised of Basement + Ground + 03 Upper Floors owned/occupied by M/s Masabaa The Treasury was issued FSC vide Letter No. F6/DFS/MS/EH/2014/WZ/1624 dated 23/12/2014. The premises was re inspected by the officers concerned of this department on **27.08.2018** in the presence of **Sh. Amit Nautiyal** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D with effect from 5/9/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...5/9/18..... at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer  


Copy to:

Sh. Amit Nautiyal (Authorised Signatory),  
M/s Masabaa The Treasury (a unit of VSR Foods India),  
37, 2<sup>nd</sup> & 3<sup>rd</sup> floor, Club Road Punjabi Bagh, New Delhi-110027

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry

INSPECTION REPORT

1. Name & address of the building : M/s Masabaa The Treasury (a unit of VSR Foods India) at premises No. 37, 2<sup>nd</sup> & 3<sup>rd</sup> floor, Club Road Punjabi Bagh, New Delhi
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2014/WZ/1624 dated 23/12/2014
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 27-08-2018
7. Name of the Inspecting Officers : Mukesh Verma DO (West), Udai Vir Singh ADO (WP)
8. Name and designation of officers
- From the building side : Mr. Amit Nautiyal
9. Year of Construction : 2008-2009
10. Applicant's letter No. : Nil dated 23/08/2018

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	As per pervious inspection/BBL	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	06 m	Provided	M.R
	• Gate width	required	Provided	M.R
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	2	2 Provided	M.R.
	• Basement	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 m & 1 m	1x106 cm , & 1x152 cm	M.R
	• Basement	Required	Provided	M.R
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	required	Provided	M.R.
	f. Door size	2 mtr	209 cm, 1 m Provided	M.R.
3.	<b>Compartmentation.</b>			
	• Fire check door	N.R.	N.R.	N.R.
	• Sealing of electrical shafts	Required	Provided	M.R.
	• Fire Rating of shaft door	N.A.	N.A.	N.A.
	• Water Curtain	N.A.	N.A.	N.A.
	• Fire Dampers	N.A.	N.A.	N.A.
4.	<b>Smoke Management System.</b>			
	• Basements	N.A.	N.A.	N.A.
	• Upper floors	Required	Provided	M.R.
5.	<b>Fire Extinguishers</b>			
	• Total numbers	08	12 Provided	M.R
	• Types	ABC, CO <sub>2</sub> Water CO <sub>2</sub> type	Provided	M.R
	• IS marking	ISI marked	Provided	M.R

6.	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	02	02 Provided	M.R
	• Length of hose reel hose	30 m required	Provided	M.R
	• Nozzle diameter	5 mm	Provided	M.R
7.	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Required	Provided	M.R.
	• Location of Main Panel	Required	Provided	M.R.
	• Location of Repeater Panel	Required	Provided	M.R.
	• Alternate source of power	Required	Provided	M.R.
	• Hooter's Location	Required	Provided	M.R.
8.	<b>MOEFA</b>	Required	Provided	M.R
9.	<b>Public Address System</b>	N.R.	N.R.	N.R.
10.	<b>Automatic Sprinkler system</b>			
	• Basement	N.A.	N.A.	N.A.
	• Upper Floor	N.R.	N.R.	N.R.
	• Sprinkler above false ceiling	N.R.	N.R.	N.R.
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N.R.	N.R.	N.R.
	• Number of hydrants per floor	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.
13.	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
	<b>Terrace level</b>			
	➤ Discharge of pump	450 LPM	Provided	M.R.
	➤ Head of the pump	30 m	Provided	M.R.
	➤ Power supply	required	Provided	M.R.
	➤ Auto Starting of pump	required	Provided	M.R.

	<b>Underground tank capacity</b>	N.R.	N.R.	N.R.
	➤ Draw -off connection	N.R.	N.R.	N.R.
	➤ Fire service inlet	N.R.	N.R.	N.R.
	➤ Access to tank	N.R.	N.R.	N.R.
	➤ Overhead Tank Capacity	10,000 ltrs	Provided	M.R.
15	<b>Exit Signage.</b>	required	Provided	M.R.
16.	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	• Pressurization of Lift lobby	N.A.	N.A.	N.A.
	• Communication In lift Car	N.A.	N.A.	N.A.
	• Fireman's Grounding Switch	N.A.	N.A.	N.A.
	• Lift Signage	N.A.	N.A.	N.A.
17.	<b>Standby power supply</b>	Required	Provided	M.R
18.	<b>Refuge Area</b>			
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19.	<b>Fire Control Room</b>			
	➤ Detector System Panel	N.A.	N.A.	N.A.
	➤ Flow Switch Panel	N.A.	N.A.	N.A.
	➤ PA system Panel	N.A.	N.A.	N.A.
	➤ Batter backup	N.A.	N.A.	N.A.
	➤ Building Floor plans	N.A.	N.A.	N.A.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. F6/DFS/MS/EH/2014/WZ/1624 dated 23/12/2014 renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.

Signature of the Inspection Officer

Name Udai Vir Singh

Designation ADO (WP)

Signature of the Inspection Officer

Name Mukesh Verma

Designation DO (West)