

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS/School/2018/SZ/2052

Dated: 7/8/18

FIRE SAFETY CERTIFICATE

Certified that the SDMC Primary Boys/Girls School, Indra Park (Palam), New Delhi-110045. ( Code: 1757171) consists of two blocks namely Old blocks & New Block, Old Block comprised of ground plus two upper floors (**not in use**) & New Block comprised of ground plus one upper floor was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2016/SZ/262 dated 18.02.2016. The said School building was re-inspected by the officer concerned of this department on 24.08.2018 in presence of Ms. Amarjeet Kaur (Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE GNCT of Delhi Circular no. 3298 to 3398 dated 01.03.2011 and that the building is fit for occupancy class B "Educational building" for New Block only with effect from...7/8/18..... for a period of **three years** subject to compliance of the conditions printed overleaf.

Issued on .....7/8/18..... at New Delhi by

  
Vipin Kental  
Chief Fire Officer

Copy to:-

1. The Director, (Education), SDMC, 23<sup>rd</sup> floor, Civic Centre, Minto Road, New Delhi.
2. The Principal SDMC Primary Boys/Girls School, Indra Park (Palam), New Delhi-110045.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1	Name & address of the building	S.D.M.C. Primary Boys/ Girls School ( ID 1757171) Indra Park (Palam) New Delhi-110045		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal New Block ( ground plus one upper floor)		
4	Details of previous NOC	Old Block F6/DFS/MS/School/2015/SZ/903 dated 03.06.2015 & New Block F6/DFS/MS/School/2016/SZ/262 dated 18.02.2016		
5	Fire safety directives letter No	DOE Circular dated 1.3.2011		
6	Date of inspection	24.08.2018		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Smt. Amarjeet Kaur (Principal)		
9	Year of construction	2003 & 2010		
10	Applicant's letter No.	22/SFC/Indrapark dated 24.07.2018	Two Blocks: Old Block Ground Plus Two upper Floors ( <b>in not of use</b> ) & School running in New Block: Ground plus <u>One</u> upper Floor.	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/DOE Cir. Dated 1.3.2011	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	6 mtrs	Provided	MR
	2) Gate width	4.5 mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Two	Two	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.50 Mtrs.	1.50 Mtrs. & 1.44 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	1 No.	2 Nos.	MR
	e. Width of corridor	1.50 Mtrs.	Provided	MR
	f. Door size	1 Mtr.	Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	N/A	N/A	N/A
	upper floors		Natural Vent.	MR

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	8 Nos. ABC OR CO2	4 Nos	MR
	Types	type	ABC	MR
	ISI marking	ISI	Provided	MR
<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR

4/11

16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	MR
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any:</b> ABC fire exting. Provided near electric meter.			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per DOE Circular dated 1.3.2011, renewal of Fire Safety Certificate issued vide letter no.F6/DFS/MS/School/2016/SZ/262 dated 18.02.2016 is recommended or new block only.

Accordingly DFA is put up for your approval and signature please.

*Self* 27/8/18

S.P. Bhardwaj  
ADO Dwarka

~~DO/SU~~

*Self* 27/8/18

929/DO(SW)  
27/08/18 DCfo (S2)

*Self* 27/8



*Chas24* m/sccu

F7/10.  
*Self* 30/8

1796/CRSL  
519.

FT is put up for signature please

*Chas24* m/sccu *Self*

*Self* 30/8/18