

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001.

No. F.6/DFS/MS/EH/2018/SZ/ 2058

Dated: 10/9/18

**FIRE SAFETY CERTIFICATE**


Certified that the **M/s Sagar Ratna Restaurant Pvt. Ltd.**, C-1, New Krishna Park, Vikas Puri, New Delhi 110018, comprised of basement, ground floor plus three upper floors but restaurant is running at ground & first floor only owned/ occupied by a M/s Sagar Ratna Restaurant Pvt. Ltd. was issued Fire Safety Certificate vide Letter No. F6/DFS/MS/EH/2015/SZ/1541 dated 26.08.2015. The Restaurant building was re-inspected by the officer concerned of this department on 14.08.2018 in the presence of Sh. Dilip Kumar (Restaurant Manager) and found that the M/s Sagar Ratna Restaurant Pvt. Ltd. have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building/premises (**Ground & First Floor only**) is fit for occupancy class Group "D" Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....10/9/18.....at New Delhi.

  
(VIPIN KENTAL)  
CHIEF FIRE OFFICER

Copy to:-

1. The Authorized Signatory,  
M/s Sagar Ratna Restaurant Pvt. Ltd.,  
C-2, 2<sup>nd</sup> Floor, Malviya Nagar, New Delhi-110017.
2. Dy. Health Officer,  
S.D.M.C, West Zone, Vishal Enclave,  
Rajouri Garden, New Delhi 110027.

9c  
  
31/8/18

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. Basement shall be used as per the building bye laws.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.



**INSPECTION REPORT**

1. Name & address of the building: M/s Sagar Ratna Restaurant Pvt. Ltd., C-1, New Krishna Park, Vikas Puri, New Delhi 110018.
2. Type of Occupancy : Group D (Assembly)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2015/SZ/1541 dated 26.08.2015
5. Fire Safety directives letter No : N.A
6. Date of inspection : 14.08.2018
7. Name of Inspecting Officers : D.O. M.K.Chattopadhyay & A.D.O. Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh. Dilip Kumar (Restaurant Manager)
9. Year of Construction : 2006-2007
10. Applicant's letter No. : Nil dated 03.07.2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dt. 26.08.2015	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	09 mtrs 4.5 mtrs N/A	Provided Directly accessible N/A	M/R M/R N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits (Restaurant at Ground &amp; First Floor only)</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	Two N/A	Three provided N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	Old case N/A	114, 94 & 86 cms. 125, 114 & 86 cms	M/R, being old case N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	One	MR
	e. Width of Corridor	150 cms	230cms	MR
	f. Door Size	Two Exit	130 & 100 cms	M/R, Being Old case
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System (Restaurant at Ground &amp; First Floor only)</b>			
	• Basements	Required	Exhaust fans are provided	M/R
	• Upper floors	Required	Natural Ventilation	M/R
5.	<b>Fire Extinguishers (Restaurant at Ground &amp; First Floor only)</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	10 no's ABC/CO <sub>2</sub> ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	<b>First-Aid Hose Reels (Restaurant at Ground &amp; First Floor only)</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on First Floor</li> <li>• Length of hose reel hose</li> </ul>	One 30 mtrs	Provided Provided	M/R M/R



<b>7.</b>	<b>Automatic fire detection and alarming system</b>	<b>(Restaurant at Ground &amp; First Floor only)</b>		
	<ul style="list-style-type: none"> <li>Type of detectors(Smoke)</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A	Provided	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M/R
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>	<b>(Restaurant at Ground &amp; First Floor only)</b>		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground &amp; First Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	M/R
		N/A	Provided	N/A
		N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>	<b>(Restaurant at Ground &amp; First Floor only)</b>		
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants</li> <li>Hose Box</li> </ul>	Required 100 mm	Provided	M/R
		One	Provided	M/R
		One	Provided	M/R
<b>12.</b>	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> </ul> </li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pump House Access</li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		900 LPM	Provided	M/R
		30 mtrs.	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity                             <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	M/R
		N/A	N/A	N/A
		5000 ltrs.	5000, ltrs. provided	M/R, being old case
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	M/R
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
<b>7.</b>	<b>Standby power supply</b>	Required	Provided	M/R
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A

N/13

Building comprised of Basement, Ground plus three upper floors but Restaurant is at Ground & First Floor only

19.	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/EH/2015/SZ/1541 dated 26.08.2015 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*[Signature]*  
23/8/18

Signature of Inspecting Officer  
Name:- M.K. Chattopadhyay  
Designation:- Divisional Officer

*[Signature]*  
21/8/18

Signature of Inspecting Officer  
Name:- Sandeep Duggal  
Designation:- Asstt. Divisional Officer

841/DO(CSO)  
dt. 23/08/18

Dy.C.F.O.( South Zone)



*[Signature]*  
24/8

CFO (S2) m.scell FT 107.  
27/8.

F.T. letter is put up for Sign. please.

1772/cfo S2  
4/9.

CFO (S2) | m.scell 4/9

*[Signature]*  
31/8/18