

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F-6/DFS/MS/2018/WZ/ 2071

Dated: 10/09/2018

FIRE SAFETY CERTIFICATE

Certified that The **Mohan's Restaurant (A Unit of Mittal Hotel Pvt. Ltd.)** Located at **First Floor, 3-4 Central Market, Ashok Vihar Phase -1, New Delhi-110052** in a building comprised of Basement + Ground + Two Upper Floors was issued FSC vide Letter No. F-6/DFS/MS/2015/WZ/1330 dated- 23/07/2015. The premises was re inspected by the officers concerned of this department on 30-08-2018 in the presence of Sh. Naveen Mittal (Owner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D with effect from 10/9/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10.09.18..... at New Delhi by.


(Atul Garg)

Chief Fire Officer
Delhi Fire Service

Copy to:

- 1 The Manager, The Mohan Restaurant, First Floor, 3-4 Central Market, Ashok Vihar Phase -1, New Delhi-110052
- 2 The Dy Health Officer, Civil line Zone, Public Health Department, 16, Rajpura Delhi.

Following fire safety directives must be adhered to:-

1. **The NOC is valid for 1st floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building bye laws.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: **The Mohan's Restaurant (A Unit of Mittal Hotel Pvt. Ltd.) Located at First Floor 3-4 Central Market, Ashok Vihar Phase -1, New Delhi-110052**
2. Type of Occupancy: **Restaurant at 1st Floor, (The building comprised of Basement + Ground + Two Upper Floors)**
3. Type of Case : Renewal
4. Details of previous NOC ; F-6/DFS/MS/2015/WZ/1330 dated- 23/07/2015
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 30-08-2018
7. Name of the Inspecting Officer : Udai Vir Singh ADO (WP), *Sh Mubesh Verma Do/W*
8. Name and designation of Officer
from the building side : Sh .Naveen Mittal
Year of Construction :
9. Applicant's letter No. : Form ,J, Dated -Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as N/15	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	12m Provided	MR
	• Gate width	Required	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	Provided	NA
	b. Width of staircases			
	• Upper floors	Required	130 cm & 115cm	MR (Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	N.R.	NR	NR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1x2m & 1x1m	Hall-1=1x1.5m, 2x1.1m & 1x1.5m Hall-2=2x1.8m & Small Room=0.9m	MR(Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	8	8 Provided	MR
	• Types	ABC, CO2 & WCO2	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	1 Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	MR
	• Location of Main Panel	NA	NA	MR
	• Location of Repeater Panel	NA	NA	MR
	• Alternate source of power	NA	NA	MR
	• Hooters' Location	NA	NA	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	180lpm	NA
	➤ Jockey pump head	NA	60lmp	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40m	40 m Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank cpty	10, 000 litres	Provided	MR
15	Exit Signage	Required	Proviided	R
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA		NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no F-6/DFS/MS/2015/WZ/1330 dated- 23/07/2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note;- The sprinklers were found provided during earlier inspection, now has been removed. However, basement not owned/ used by The Mohan and have separate entry/exit. FSC is recommended for 1st floor only.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

[Handwritten signature]
30/8/18

[Handwritten signature]
30/8/18

Name Udai Vir Singh

Name Sh Mukesh Verma

Designation ADO (WP)

Designation DO/W

[Handwritten signature]
Dy. CPO (WZ)
CFO West
6/9/17
5/9/18

[Handwritten signature]
ADU RND
Sir, F.P./FSC is put up for signature please.
[Handwritten signature]
7/8/18

[Handwritten signature]
CPO (WZ)
10/9/17

M