

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZ/ 2097

Dated: 13/9/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Arwachin Bharti Bhawan Sec. School at Balbir Nagar, Shahdara, Delhi - 110032, comprised of Ground plus one upper floors owned / occupied by Arwachin Bharti Bhawan Sec. School was issued FSC vide letter No. F.6/DFS/MS/School/2015/NDZ/452 dated 27/03/2015. The school building was re-inspected by the officer concerned of this department on 29/08/18 in presence of Smt. Kusum Lata, Vice Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17/01/2005 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 13/9/18 for a period three year, subject to conditions printed overleaf.

Issued on.....13/9/18.....at New Delhi by

13/9/18

(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

o/c
of

To,
The Vice Principal,
Arwachin Bharti Bhawan Sec. School,
Balbir Nagar, Shahdara, Delhi - 110032,

Copy to:-
The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi- 110053.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3 All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4 The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
- 5 This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Arwachin Bharti Bhawan Sec. School,
Balbir Nagar, Shahdara, Delhi - 110032.
2. Building is comprised of : G+1
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2015/NDZ/452 dt. 27/03/2015
6. Fire Safety circular No : circular No. 262-362 dated 17/01/2005.
7. Date of Inspection : 29/08/18
8. Name of the Inspecting officers : ADO Om Prakash
9. Name and designation of Officer
from the building side : Smt. Kusum Lata (Vice Principal)
10. Year of Construction : 1984
11. Applicant's letter No : NIL Dated - 16/08/18

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement Circular 2005	Provided at Site	Remark MR/NMF
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 Mtrs N/A N/A	06 Mtrs N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	02 no. N/A	03 no. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 m	1.5 m & 1.0 m x 2	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace			
		01 no.	02 no.	MR
	g. Width of Corridor			
	h. Door Size	1.5 m	2.0 m	MR
		1.0 m	1.0 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A N/A	N/A N/A	N/A N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types 	07 nos. ABC & Co2	10 nos. ABC & Co2	MR MR
	<ul style="list-style-type: none"> • ISI marking 	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	02 no.	02 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	220 lpm	220 lpm	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A

M/S

	• Overhead Tank capacity	2500 Ltrs.	5000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules.

The Fire safety Certificate issued vide letter no. F.6/DFS/MS/School/2015/NDZ/452 dated 27/03/2015 has grant under circular No. 262-362 dated 17/01/2005 is recommended to renewal under rule 37 of the Delhi Fire Service Rule 2010.

Om Prakash
4/9/18

Signature of the Inspecting Officer
Name: Om Prakash
Designation: ADO(Shahdara)

690 / 13-9-18

DO/East *[Signature]*
4/9/18
[Signature]
Dy. CPD/NDZ

G.F.C. mscell F710
W
7F

Sir, F.T. Letter is put up for your kind review +