

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/2015/MD2/2103

Dated: 13/9/18

FIRE SAFETY CERTIFICATE

Certified that the EDMC Primary School No.-1 at Mandawali Fazalpur, Delhi-92, owned/occupied by EDMC Primary School No.1, comprised of ground plus one upper floor was issued FSC vide letter No. F.6/DFS/MS/School/2015/657 Dated-01/05/15. The school building was inspected by the officer concerned of this department on 28/08/18 in the presence of Mr. Dinesh Kumar (Incharge) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular F16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and the school building is fit for occupancy class "B" 'Educational Building' for ground plus one floor only with effect from 13/9/18 for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....13/9/18..... at New Delhi by

W
13/9
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,

The Principal,(1st shift)
EDMC Primary School No.-1,
Mandawali Fazalpur, Delhi-92

Copy to:-

1. The Director of Education, EDMC,
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-92.
2. The Principal, (2 nd shift)
EDMC Primary School No.-1,
Mandawali Fazalpur, Delhi-92.

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

- N/B
1. Name & address of the building : EDMC Primary School No.-1 at Mandawali Fazalpur, Delhi-92.
 2. Building is comprised of : G+1 upper floor
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC letter : F6/MS/DFS/School/NDZ/657 dated 01/05/15
 6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11
 7. Date of Inspection : 28/08/18
 8. Name of the Inspecting officers : ADO R.K. Yadav
 9. Name and designation of
Officer from the building side : Mr. Dinesh Kumar (Incharge)
 10. Year of Construction : 2009-10
 11. Applicant's letter No : Nil Dated 13/08/18

NO	Minimum Standards on fire prevention and fire safety as per circular no.3298 to 3398 dt-01.03.11	Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 M	06 M	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 M	1.5 M each	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 No.	2 No.	MR
	g. Width of Corridor	1.5 M	2 M	MR
	h. Door Size	1.0 M	1.0 M	MR
	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	06 Nos.	08 Nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

N/14

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

N/15

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F6/MS/DFS/School/NDZ/657 dated 01/05/15 renewal under the circular no. F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11 is recommended.

R. K. Yadav
27/8/18

Signature of the Inspecting Officer
Name: R. K. Yadav
Designation: ADO(LN)

DO(ED) *[Signature]*
30/8/18

635/CFD(MD2)
18/9/18 DYUB/MD2

[Signature]

CFD M. Scell

FTM.
[Signature]
7/3

Copy FT letter is put up for signature please

[Signature]
01/9/2018