

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZI/ 2098

Dated: 13/9/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Nav Jeevan Shiksha Samiti, K-34, Gali No-12, Bhram puri Delhi - 110053, comprised of Ground plus three upper floors Owned / occupied by Nav Jeevan Shiksha Samiti. The school building was inspected by the officer concerned of this department on 16/08/18 in presence of Sh. Nathu Singh, Manager of the school and found that the school building have complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 13/9/18 for a period three year, subject to conditions printed overleaf.

Issued on 13/9/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

ok
ok

Copy to:-

1. The Manager,
Nav Jeevan Shiksha Samiti,
K-34, Gali No-12, Bhram Puri,
Delhi -110053.
2. The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi -110053.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3 All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4 The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
- 5 This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Nav Jeevan Shiksha Samiti,
K- 34, Gali No -12, Bhramपुरi, Delhi -110094.
2. Building is comprised of : (G+3)
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous FSC letter : N/A
6. Fire Safety direction letter No : NBC Part IV
7. Date of Inspection : 16/08/2018
8. Name of the Inspecting officers : ADO Om Prakash
9. Name and designation of Officer
from the building side : Sh. Nathu Singh (Manager)
10. Year of Construction : 2006
11. Applicant's letter No : Nil (Registration No. S/19286/1988) Dated -26/07/18

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement as per NBC	Provided at Site	Remark MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 Mtrs N/A N/A	06 Mtrs N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	01 no. N/A	02 Nos. N/A	MR N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 m N/A	1.5 & 1.4 mtr N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01 no	01 no	MR
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A N/A	N/A N/A	N/A N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types 	07 nos. ABC & Co2	14 nos. ABC & Co2	MR MR
	<ul style="list-style-type: none"> • ISI marking 	ISI marked	ISI marked	MR

4/2

6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	05 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	MR
9	Public address System.	N/A	N/A	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	M/R
	➤ Head of the Pump	40 M	40 M	M/R
	➤ Power supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 Liters	10000 Liters	M/R
15	Exit Signage.	Required	Provided	M/R

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules.

Om Prakash
29/8/18

Signature of the Inspecting Officer
Name: Om Prakash
Designation: ADO (Shahdara)

DO (East) *Prof*
30/8/18.

DY (CB) MDZ
dh

CFP. *m.scell* *FT/DO.*
u
7/9.

Sir, f.t. letter is put up for your kind signature please.

CF.O (MDZ)

m.scell *u*
13/9.

Om Prakash
12/9

689/CB/MDZ
13-9-18