

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/School/2015/1545

Dated: 19/9/18

FIRE SAFETY CERTIFICATE

Certified that the **Beni Pershad Jaipuriya Public School** located at YP-Block, Behind D.D.A Market, Pitampura, Delhi-110088 comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/School/2015/1545 Dated 26/08/2015. The premises was re inspected by the officer concerned of this department on **12-09-2018** in the presence of Smt. Anjali (Headmistress) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01-03-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 19/9/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on19/9/18..... at New Delhi by.


(Anil Garg)
Chief Fire Officer,

Copy to:

1. The Authorised Signatory,
Beni Pershad Jaipuriya Public School
YP-Block, Behind D.D.A Market, Pitampura, Delhi-110088.
2. The Director of Education, Old Secretariat, Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Beni Pershad Jaipuriya Public School** located at YP-Block, Behind D.D.A Market, Pitampura, Delhi-110088.
2. Type of Occupancy : Educational (Ground + 2 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2015/1545 Dated 26/08/2015
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 12-09-2018
7. Name of the Inspecting Officer : Mukesh Verma, DO (West)
8. Name and designation of Officer
from the building side : Smt. Anjali (Headmistress)
9. Year of Construction : 2003
10. Applicant's letter No. : nil dated 28/08/2018

Plot area=799 m²
 Covered area=532m²
 No. of Students=175
 No. of class rooms=12

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Cr.No.3298-3398 dated 01-03-11 | Provided at site | Remarks MR/NMR |
|------|---|--|--|--|
| 1. | Access of building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | <ul style="list-style-type: none"> Accessible Accessible NA | <ul style="list-style-type: none"> Provided Provided NA | <ul style="list-style-type: none"> MR MR NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper floors • Basements | <ul style="list-style-type: none"> 1 NA | <ul style="list-style-type: none"> 02 Provided NA | <ul style="list-style-type: none"> MR NA |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper floors • Basements | <ul style="list-style-type: none"> 1x150 cm NA | <ul style="list-style-type: none"> 2x140 cm NA | <ul style="list-style-type: none"> MR NA |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | <ul style="list-style-type: none"> NR NR | <ul style="list-style-type: none"> NR NR | <ul style="list-style-type: none"> NR NR |
| | d. No of continuous staircase to terrace | | | |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size (Class room) | 1 mtr | 1x1 mtr (less than 45 student in all class room) | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | <ul style="list-style-type: none"> NA NA NA NA NA | <ul style="list-style-type: none"> NA NA NA NA NA | <ul style="list-style-type: none"> NA NA NA NA NA |
| 4. | Smoke managements System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | <ul style="list-style-type: none"> NR NR | <ul style="list-style-type: none"> NR NR | <ul style="list-style-type: none"> NR NR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | <ul style="list-style-type: none"> 4 nos. ABC & CO₂ ISI marked | <ul style="list-style-type: none"> Provided Provided Provided | <ul style="list-style-type: none"> MR MR MR |

| | | | | |
|-----|--|-----------|----------|----|
| | floor | 30m | Provided | MR |
| | • Length of hose reel hose | 5mm | Provided | MR |
| | • Nozzle diameter | | | |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements: | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 450 lpm | Provided | MR |
| | ➤ Head of the pump | 40mtr | Provided | MR |
| | ➤ Power supply | NA | NA | NA |
| | ➤ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | Provided | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000Ltr | Provided | MR |
| 15. | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2015/1545 Dated 26/08/2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Mukesh
12/9/18

Signature of the Inspecting Officer

Name Mukesh Verma

Designation DO (West)

~~DO (W2)~~
~~19/9/17~~
CFO West
19/9/17
*IP

DO/W
F.V. letter is put up for signature please

~~CFO (W2)~~
~~10/9/17~~

Mukesh
12/9/18

M