

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO.F6/DFS/MS/School/2018/SZ/ 2129

Dated: 18/9/2018

FIRE SAFETY CERTIFICATE

Certified that the Indraprastha International School located at Sector-10, Dwarka, New Delhi-110075, comprised of basement ground plus three upper floors owned/occupied by Kanta Devi Charitable Education Society (Regd.) was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2016/SZ/133 dated 19.01.2016. Now the management has constructed one more upper floor, building is comprised of basement, ground plus Four upper floors & have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire Service Rules 2010, Verified by the officers concerned of fire service on 10.9.2018 in presence of Sh. Shyam Sunder (PRO) and that the premises/building is fit for occupancy class B "Educational building" with effect from...18/09/2018.. for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on18/09/2018..... at New Delhi by

18/9
Vipin Kental
Chief Fire Officer

Copy to:-

1. The Dy. Director, (Education), G.N.C.T of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal Indraprastha International School located at Sector-10, Dwarka, New Delhi.
3. The Dy. Director (L&I), Builg., DDA, Vikas Sadan, INA, New Delhi.

CONDITIONS

1. Access road for fire tenders movement all around the building shall be kept free from any hindrance.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT


1	Name & address of the building	Inderaprastha International School, Sector 10, Dwarka, New Delhi-110075.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New (B+G+4 upper floors) Addition/ Altration		
4	Details of previous NOC	F6/DFS/ MS/School/ 2016/SZ/133 Dated 19.1.2016 (B+G+3)		
5	Fire safety directives letter No	F6/DFS/MS/BP/2017/SCHOOL/22 dated 06.02.2017		
6	Date of inspection	10.9.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj(ADO Dwarka)		
8	Name and designation of officers from the building side	Sh. Shyam Sunder Prashad (PRO)		
9	Year of construction	2003 & 2018		
10	Applicant's letter No.	IPIS /18/PRO/DFS/18/199 dated 4.9.2018	Basement ground plus four upper floors	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ Letter dated 6.2.2017	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	12 Mtrs.	Provided	MR
	2) Gate width	06 Mtrs.	Provided	MR
	3) Width of internal road	06 Mtrs	Provided.	MR
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	4 Nos.	4 Nos.	MR
	2. basements	5 Nos.	7 Nos.	MR
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	Provided	MR
	2. basements	1.50 & 2 Mtrs.	1.50 (5 Nos.) & 2 Mtrs. (2 Nos.)	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	4 No.	4 No.	MR
	e. Width of corridor	1.50 Mtrs.	Provided	MR
	f. Door size	1 Mtr. & 1.20 Mtrs. At 4th floor (Class rooms) & 1.50 to 2 Mtrs. In Stairecases	Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Sealed	MR
	3. Fire Rating of shaft door	Required	Provided	MR
	4. water curtain	Required	Provided	MR
	5. Fire dampers	Required	Provided	MR
4	Smoke Management system.			
	basement	30 ac charge 12 ac charge	Provided	MR
	upper floors		Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	As per IS 2190/1992	Provided	MR
	Types	CO2 & ABC Type ISI	CO2 & ABC	MR
	ISI marking	Marked	ISI Marked	MR

4/28


17	Standby power supply	Required	DG Set 180 KVA	MR
18	Refuge Area.	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. detector system Panel	Required	Provided	MR
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	Required	Provided	MR
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	Required	Provided	MR
20	Special Fire Protection systems for protection of special risks, if any: Manual operated CO2 in HT & LT Panels			M/R

The Fire protection systems provided in the building were checked & found functional at the time of inspection. Keeping in view compliance of the minimum standards on fire prevention & fire safety requirements under the rules, issuance of fire safety certificate is recommended under rule 35 of the Delhi Fire Service Rules 2010 under Act 2007.


Accordingly DFA is put up for approval and signature please.




 S.P. Bhardwaj
 ADO (Dwarka)




 13/9/18

DCFB (SZ)
 869/20/SW
 13/9/18
 21/cfo SZ
 18/9


 14/9
 FTB.
 m/s cell
 18/9.

FT is put up for signature please

 18/9/18
 m/s cell

 18/9.