

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001
Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2018/SZ/ 2121

Dated: 17/9/18

FIRE SAFETY CERTIFICATE

Certified that Scholars Home International School located at B-7/164,Phase-IV, Bandh Road, Aya Nagar Extension, New Delhi-110047 comprised of ground plus two upper floors owned/occupied by Under The Aegis Of Ch. Pawan Singh Educational & Charitable Trust was granted Fire Safety Certificate by this department vide letter No. F.6/MS/DFS/School/2015/SZ/1860 dated 16/10/2015. The premises was re-inspected by officer concerned of this department on 24/08/2018 in presence of Mrs. Chanchal (Principal) and observed that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/9/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to: -

1. The Principal, Scholars Home International School,B-7/164,Phase-IV, Bandh Road, Aya Nagar Extension, New Delhi-110047
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

2/6

INSPECTION REPORT

1	Name & Address of the Building	Scholars Home International School, B-7/164, Phase-IV, Bandh Road, Aya Nagar Extension, New Delhi-110047		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	G+02 upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/MS/DFS/School/2015/SZ/1860 Dated 16/10/2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	24-08-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mrs. Chanchal (Principal)		
10	Year of construction	2005		
11	Applicant letter No.	Nil dated 27.06.2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	6 mtr -NA- -NA-	Provided -NA- -NA-	MR -NA- -NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> Upper floors. Basement floor. 	Two -NA-	Two -NA-	MR -NA-
	b) Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	1.5 mtr -NA-	1.56m & 0.87m -NA-	MR -NA-
	c) Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	1.5m	Provided	MR
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	30 ACPH 12 ACPH	-NA- -NA-	-NA- -NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	12 Nos ABC / CO2 ISI marked	12 Nos ABC & Co2 Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	One 30m 5mm	Provided Provided Provided	MR MR MR


2/8

19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	ABC type fire extinguisher provided near electrical panel	-NA-

The Fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, FSC issued vide letter No. F.6/MS/DFS/School/2015/SZ/1860 dated 16/10/2015, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.



Signature of the Inspecting Officer
Name: Mehmoed
Design: ADO (SJ)

~~DO (SD)~~

Amal
31/8/18

dy. CFO (S2)



Amal
31/8

CFO (S1)

M.Scell

FTM.

Uc
7/9/18

11/CFO S2
14/9.

A. G. T. Lehar *Signature blank*

200 CSF2

M.Scell

Uc
14/9.

Amal
13/9/18