

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2018 / W2 / 2146

Dated: 19 / 9 / 2018

FIRE SAFETY CERTIFICATE

Certified that the **Amba Cinema** located at **Subzi Mandi, Ganta Ghar, Delhi-110007** comprised of **ground and 02 upper floors** owned/ occupied by **Amba Cinema** was issued fire safety certificate vide letter no. **F6/MS/DFS/2011/1290 Dated: 22/06/2011** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety accordance with rule 33 of the Delhi Fire Service rule 2010 and verified by the officer concerned of Delhi Fire Service on **31.08.2018** in the presence of **Sh. G.K. Sharma (Manager)** and that the premises is fit for occupancy Group Class-D Assembly with effect from **19 / 9 / 2018** for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on 19/9/18 at New Delhi by

(Atul Garg)
Chief Fire Officer
Ph:-011-23414250

Copy to :-

1. The Manager, Amba Cinema, Subzi Mandi, Ganta Ghar, Delhi-110007.

INSPECTION REPORT

1. Name & address of the building : Amba Cinema, Subzi Mandi, Ganta Ghar, Delhi-110007.
2. Type of Occupancy : Assembly (Ground +02 upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/2011/Cinema/1290 Dated: 22/06/2011
5. Fire Safety directives letter No :
6. Date of inspection : 31.08.2018
7. Name of the Inspecting Officers : ADO/RN
8. Name and designation of officers from the building side : Sh. G. K. Sharma, Manager
9. Year of Construction :--
10. Applicant's letter No. : Nil dated 27/07/2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Delhi Cinematograph Rules	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9m	12m	MR
	• Gate width	06 m	06m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Old case,02	02,Old case	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	Old case	1.50m each Old case	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	02	02	MR
	e. Width of Corridor	Old case	1.50m Old case	MR
	f. Door Size	Old case	1.50m Old case	MR(old case)
3	Compartmentation.			
	• Fire check door	Required	Provided	MR

h

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	25nos	3 nos	MR
		WCO2, DCP type	11-Co2, 17- WCO2 , 03- DCP type	MR
		ISI marked	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required	Provided, 03	MR
		30m	Provided	MR
		5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	4"	Provided	MR
		One	Provided	MR
		Required	Provided	MR
12	Yard Hydrants.			

	<ul style="list-style-type: none"> Total number of hydrants 	Required	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	MR
13	Pumping Arrangements.			
	➤ Ground Level	2280 lpm	2280 lpm	MR
	➤ Discharge of main Pump	60m	60m	MR
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access			
	<ul style="list-style-type: none"> Terrace level 			
	➤ Discharge of pump	450 lpm	450 lpm	MR
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	50,000ltrs	50,000ltr	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 ltrs	27,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication In lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> Lift Signage 	NA	NA	NA

		NA	NA	NA
17	Standby power supply	Required	Provided (110 KVA)	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standard on the fire prevention and fire safety required under the rules, FSC issued vide letter no F6/MS/DFS/2011/1290 Dated: 22/06/2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

RK 10/19

Signature of the Inspecting Officer
Name :- Rajesh Kumar
Designation:- ADO/RN

Sycho/w2

cto west

AD/RN

cto/w2

As approved, for letter is put up for your signature PI

10/19

179/14

FTR

10/19