

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/EH/2018/SZ/ 2167

Dated: 20/9/18

FIRE SAFETY CERTIFICATE

Certified that the restaurant in the name & style of "The Golden Dragon" located at O-13, Lajpat Nagar-II, New Delhi-110024, running at ground floor of a building comprised of basement, ground plus three upper floors was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/EH/2013/767 dated 22/08/2013. The restaurant premise was re-inspected by the officer concerned of this department on 01/09/2018 in the presence of Mr. Pawan Sachdeva (Manager) of the restaurant and observed that the restaurant running at ground floor only have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" Group-D (Restaurant) with effect from 20/9/2018 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/9/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225


Copy to: -

1. Manager, M/s Golden Dragon Restt. located at O-13, Lajpat Nagar-II, New Delhi-110024
2. DHO, South MCD, Public Health Department, Central Zone, Lajpat Nagar, New Delhi-24

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	M/s The Golden Dragon Restaurant at O-13, Lajpat Nagar-II, New Delhi-110024		
2	Type of Occupancy	Assembly, "Group-D" (Eating House)		
3	Building Comprised of	Basement, Ground, Mezzanine plus three upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/2013/767 dated 22-08-2013		
6	Fire Safety Directives Letter No	F6/DFS/MS/EH/2005/718 dated 04-04-2005		
7	Date of Inspection	01-09-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Pawan Sachdeva (Manager)		
10	Year of construction	1996-97	Restt running at ground floor only. Basement is not occupied by restaurant management.	
11	Applicant letter No.	Outdoor Diary No. 11828 dated 20-08-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	12 mtr	MR
	• Gate width	-NA-	Accessible from road	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.	-NA-	Others property	-NA-
	b) Width of Staircase			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	Others property	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	One	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	02 exits	1.5m & 0.90m	MR (old case)
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors / Restt. area	12 ACPH	Provided in kitchen	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	06 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

The Golden Dragon Restt at O-13, Lajpat Nagar-II, New Delhi-110024

N/14

19.	Fire Control Room. <ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building/ premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/EH/2013/767 dated 22/08/2013, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Mehmood
21/9/18

Signature of the Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

The Golden Dragon Restt at O-13, Lajpat Nagar-II, New Delhi-110024

DO (SD)

Mehmood
10/9/18

DO (SD)

Lajpat
10/9



Chf 527 m'scell FTM. 11/9.

A. B.T. letter put up for signature please

Mehmood
13/9/18 (ADO (SJ))

Chf 527 m'scell 18/9.

28/9/18