

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/Club/2018/SZ/ 2178

Dated: 24/9/18

FIRE SAFETY CERTIFICATE

Certified that M/s **Gulmohar Sport-cum-Community Centre** located at Gulmohar Park, New Delhi-110049, comprised of basement, ground plus one upper floor owned/occupied by Gulmohar Sport-cum-Community Centre was issued NOC by this department vide letter No. F6/DFS/MS/2006/735 dated 23/03/2006. The premise was re-inspected by officer concerned of this department on 29/08/2018 in the presence of Mr. Trilok Singh (Manager) and found that premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" (Club) with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 24/9/18 at New Delhi by

20/9
(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225


Copy to:

1. The Ex. Engineer (Bldg), S.D.M.C., Jal Vihar, Lajpat Nagar-III, New Delhi-110024
2. Manager, Gulmohar Sport-cum-Community Centre, Gulmohar Park, New Delhi-110049

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of DFS Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of
6. UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	Gulmohar Sports-cum-Community Centre, Gulmohar Park, New Delhi-110049		
2	Type of Occupancy	Assembly (Sport Club-cum-Community Centre)		
3	Building Comprised of	Basement, Ground + 01 upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2006/735 Dated 23-03-2006		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/97/1756 Dated 20-11-1997, F.6/DFS/MS/BP/98/1888 Dated 18-09-1998 F6/DFS/MS/2006/735 dated 23-03-2006		
7	Date of Inspection	29-08-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Trilok Singh (Manager)		
10	Year of construction	2006		
11	Applicant letter No.	Nil dated 09/07/2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Directives requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	18 mtr	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	02 Nos	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	1.5 mtr	1.18m & 1.10m	MR (old case)
	➤ Basement floor	1.5 mtr	1.4m each	MR (old case)
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Two	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1.2m	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan	MR
	• Upper floors.	12 ACPH	Natural ventilation	MR
5.	Fire Extinguishers.			
	• Total numbers	One/300 m ²	20 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One/1000 m ²	02 Nos	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

Gulmohar Sports-cum-Community Centre at Gulmohar Park, New Delhi-49

7.	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	100 mm	Provided	MR
	• Number of Hydrant per floor	02 Nos	Provided	MR
	• Hose box.	02 Nos	Provided	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	Required	Provided	MR
	• Hose box.	Required	Provided	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	1620 LPM	1620 LPM	MR
	➤ Head of main pump.	Required	55m	MR
	➤ Number of main pumps.	One	One	MR
	➤ Jockey Pump output.	180 LPM	180 LPM	MR
	➤ Jockey Pump head.	Required	55m	MR
	➤ Standby Pump output.	1620 LPM	1620 LPM	MR
	➤ Standby Pump head.	Required	55m	MR
	➤ Auto Starting / Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	40m	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	30,000 Ltr	Provided	MR
	➤ Draw-off connection.	Required	Required	MR
	➤ Fire Service Inlet.	Required	Required	MR
	➤ Access to tank.	Required	Required	MR
	• Overhead tank capacity.	12,500 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19.	Fire Control Room. <ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The Fire protection systems provided in the building/ premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/2006/735 dated 23.03.2006, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Mehmood
18/9/18

Signature of the Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

Gulmohar Sports-cum-Community Centre at Gulmohar Park, New Delhi-49

~~DO (SD)~~

Prakash
17/9/18

CPD/SJ

Sharma
18/9

CPD - SJ *m.scell* *F 7/18*
19/9

A. C. T. letter sent up for signature please

Mehmood
18/9/18
ADO (SJ)

CPD/SJ *m.scell* *19/9*



13/CPD/SJ
18/9/18