

NO. F6/DFS/MS/ 2018/WZ/ 2177

DATED: 24/9/18

FIRE SAFETY CERTIFICATE

Certified that the M/s The Imperial Banquet (A Unit of Silk Hospitality) formally know as Golden Crown at Ground Floor, 36, Rama Road, Industrial Area, New Delhi-110015 comprised of basement, ground plus one upper floor was granted FSC by this department vide letter no. F6/DFS/MS/Bnqt/2015/WZ/1017 Dated 17.06.2015. The premises was re-inspected by the officers concerned of Fire Service on 14.09.2018 in the presence of Sh. Rajeev Mahajan (Partner) of the banquet and observed that fire safety norms as required under rule 33 of Delhi Fire Service Rules 2010 are deemed complied and that the building is fit for occupancy class D " Assembly Building (ground floor only) " with effect from...24.9.18.....for a period of 3 (three) years, accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,subject to condition as mentioned below.

Issued on.....24/9/18..... at New Delhi by


Atul Garg
Chief Fire Officer

Copy To:-

1. The Dy. Health Officer, Karol Bagh Zone, NDMC, Public Health Department, Karol Bagh, New Delhi.
2. Sh. Rajeev Mahanjan (Partner), The Imperial Banquet (A Unit of Silk Hospitality) at ground floor, 36, Rama Road, Industrial Area, New Delhi, New Delhi-110015.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	M/s The Imperial Banquet (A Unit of Silk Hospitality) at Ground Floor, 36, Rama Road, Industrial Area, New Delhi, New Delhi-110015
2	Type of Occupancy	"D" Assembly Building (Banquet Hall)
3	Building comprised of	basement ground plus one upper floor (Banquet is runing at ground floor).
4	Type of case	Renewal
5	Details of previous NOC	F6/DFS/MS/Bnqt/2015/WZ/1017 Dated 17.06.2015
6	Fire safety directives letter No	No
7	Date of inspection	14.09.2018
8	Name of the inspecting Officers :	DCFO (WZ) & DO (W)
9	Name and designation of officers from the building side	Sh. Rajeev Mahajan(Partner)
10	Year of construction	2014
11	Applicant's letter No.	Party letter No.Nil dated 21.04.2015 and DHO/KBZ/2018/1371 dated 14.09.2018

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	------------------

1	Access to building			
	1) Road width	12 Mtr	Provided	MR
	2) Gate width	4.5 Mtr	Directly Access to Road.	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2X2M	2x2m, 1.59 & 0.94 Mtr	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	30 a/c per hour	N/A	N/A
	upper floors	12 a/c per hour	Provided	MR

5	Fire Extinguishers			
	Total numbers		8 Nos.	MR
	Types		ABC Co2 Water Co2	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	Two	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	Required	Ground Floor	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battery Backup	MR
	hooter's location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	N/A	0	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	Provided	MR
	Number of Hydrants per floor	Two	Provided	MR
	hose Box	Two	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	Provided	MR
	b. Head of main pump	N/A	Provided	MR
	c. Number of main pumps	N/A	Provided	MR
	d. jockey pump out put	N/A	Provided	MR
	e. jockey pump head	N/A	Provided	MR
	f. Standby Pump output	N/A	Provided	MR
	g. Stanby Pump head	N/A	Provided	MR
	h. Auto Starting/Manual stopping	N/A	Provided (Both)	MR
	pump house access	N/A	Provided	MR
	2. Terrace level			
	a. Discharge of pump	900 LPM	900 LPM Provided	MR
	b. head of the pump	40 M	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	20,000 ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR

	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/DFS/MS/Bnqt/2015/WZ/1017 Dated 17.06.2015** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D.P. Bhardwaj

Designation : DCFO (West Zone)

Signature of the inspecting officer

Name Mukesh Varma

Designation:- DO (West)

cfo. west
[Signature]
20/9/17

FTD

DO West

F.T. / RSC is put up for signature please.

cfo (WZ) [Signature]
20/9/17

[Signature]
24/9/18