

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO. F6/DFS/MS/2018/SZ/ 2214

Dated: 01/10/18

FIRE SAFETY CERTIFICATE

Certified that the CCRT Building at Plot No. 15A, Sector-7, Dwarka, New Delhi-110075, comprised of ground plus two upper floors with a small basement and auditorium building comprising lower ground and first floor was issued Fire Safety Certificate by this department vide letter no. F6/MS/DFS/2014/621 dated 20.05.2014. The said building was re-inspected by the officer concerned of this department on 24.9.2018 in presence of Sh. Vinod Katariya (Section Officer) & Sh. Surinder Malik (Electrical Engineer) and found that the premises have deemed complied with fire prevention and fire safety measures in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that the building is fit for occupancy class 'B2' "Educational Building" with effect from ~~01/10/18~~ for a period of **three years**, subject to compliance of the conditions printed overleaf.

Issued on ... 01/10/18 ... at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to:-

1. Dr. Chetan Singh, Director (In-charge), CCRT Building, Plot No. 15A, Sector-7, Dwarka, New Delhi-110075.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	C C R T Building Plot No. 15 A , Sector-7, Dwarka, New Delhi-110075		
2	Type of Occupancy	Educational B-2		
3	Type of case	Renewal		
4	Details of previous NOC	F6/ MS/DFS/2014/SZ/621 dated 20.5.2014		
5	Fire safety directives letter No	F6/DFS/ MS/BP/96/487 dated 10.4.1996		
6	Date of inspection	24.9.2018		
7	Name of the inspecting Officers :	Satpal Bhardwaj ADO (Dwarka)		
8	Name and designation of officers from the building side	Sh. Surinder Malik (Electrical Engineer) & Sh.Vinod Katariya (Section Officer)		
9	Year of construction	2003		
10	Applicant's letter No.	CCRT/11013/11/2017/6742 dated 28.8.2018		
		Ground + Two upper floors with small basement & Auditorium at Lower ground & 1st Floor		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement/ letter dated 10.4.1996	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	5 Mtrs.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	4 Nos.	MR ✓
	2. basements	2 No.	2 Nos.	MR ✓
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs.	1.75 Mtr. (1 No.) 1.45 Mtrs. (3 Nos.)	MR being old case
	2. basements	1.50 Mtrs.	1.25 & .76 to 80 Mtrs.	MR being old case
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	3 Nos.	3 Nos.	MR
	e. Width of corridor	N/A	1.70 Mtrs.	MR
	f. Door size	1 Mtrs.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	Required	Exhaust fans Provided	MR
	upper floors	N/A	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	26 Nos.	Provided	MR
	Types	WCO2, CO2 & DCP	CO2, ABC, DCP	MR
	ISI marking	ISI Marked	ISI Marked	MR

N117			
6	First-Aid Hose Reels.		
	total numbers on each floor	3 Nos. each floor	Provided MR
	Length of Hose reel hose	30 M	30 M MR
	Nozzle Diameter	5 mm	5 mm MR
7	Automatic fire detection and alarming system		
	Type of detectors	Smoke	Provided MR
	location of Main Panel	Ground Floor	Ground Floor near staircase MR
	location of Repeater panel	N/A	N/A
	Alternate source of power	Battery backup	Provided MR
	hooter's location	Corridor	Provided MR
8	MOEFA	Required	Provided MR
9	Public Address System.	Required	Provided MR
10	Automatic Sprinkler System.		
	basement	Required	Provided MR
	upper floors	N/A	N/A
	sprinkler above false ceiling	N/A	N/A
11	Internal Hydrants		
	Size of riser/down-corner	100 mm	Provided MR
	Number of Hydrants per floor	3 Nos. each floor	Provided MR
	hose Box	Required	Provided MR
12	Yard Hydrants.		
	total number of hydrants	Two	Two MR
	hose box	Required	Provided MR
13	Pumping arrangements		
	1. Ground level		
	a. Discharge of main Pump	1620 LPM	Provided MR
	b. Head of main pump	56 Mtrs.	56 Mtrs. MR
	c. Number of main pumps	One	One MR
	d. jockey pump out put	180 LPM	180 LPM MR
	e. jockey pump head	56 Mtrs.	56 Mtrs. MR
	f. Standby Pump output	1620 LPM	1620 LPM MR
	g. Stanby Pump head	56 Mtrs.	56 Mtrs. MR
	h. Auto Starting/Manual stopping	Required	provided MR
	i. pump house access	Required	Provided MR
	2. Terrace level		
	a. Discharge of pump	450 LPM	450 LPM MR
	b. head of the pump	40 Mtr	40 Mtr MR
	c. Power supply	Required	Provided MR
	d. Auto starting of pump	Required	Provided NMR
14	Captive water storage for fire fighting		
	1. Underground tank capacity	100000 Ltrs.	Provided MR
	a. Draw-off connection	Required	Provided MR
	b. fire service inlet	Required	Provided MR
	c. Access to tank	Required	Provided MR
	Over head tank Capacity	5000 Ltrs. each block	Provided MR
15	Exit Signage.	Required	Provided MR
16	Provision of lifts.		
	a. Pressurization of lift shaft	N/A	N/A N/A
	b. pressurization of lift lobby	N/A	N/A N/A
	c. communication in lift car	N/A	N/A N/A
	d. Fireman's grounding switch	N/A	N/A N/A
	e. Lift signage	N/A	N/A N/A
17	Standby power supply	Required	DG Set MR

18	Refuge Area.			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Battery backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection System for Protection of special Risks, if any:	CO2 Fire extinguisher provided near electric panel MR		

Fire protection systems provided in the building were checked found functional at the time of inspection. Shortcomings issued vide letter no. F6/DFS/MS/SZ/2017/1722 dated 7.7.2017 found rectified. Keeping in view deemed compliance of the minimum standards on Fire prevention & Fire Safety requirements under the rules, renewal of FSC issued vide letter no. F6/DFS/2014/SZ/621 dated 20.05.2014 is recommended.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
24/9/18

S.P. Bhardwaj
ADO (Dwarka)

D/SW

1056/DOCS-07
dt-26/09/18

[Signature]
26/9/18

DCFO (S2)

56/Chs2
29/9/18

[Signature]
27/9



CFO S2

miscell

FT/07.

[Signature]
27/9

FT is put up for signature please.

[Signature]

miscell [Signature]
1/10

[Signature]
11/10/18