

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO.F6/DFS/MS/School/2018/SZ/ 2213

Dated: 01/10/18

FIRE SAFETY CERTIFICATE

Certified that the Deep Parmarth Secondary School, Puran Nagar, Mehrauli Road, New Delhi-110077, comprised of ground floor plus two upper floors was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS//2010/1935 dated 30.06.2010. The said school building was re-inspected by the officer concerned of this department on 19.09.2018 in presence of Ms. Meena Sehrawat (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17.1.2005 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from.....01/10/18... for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on01/10/18..... at New Delhi by


Vipin Kental
Chief Fire Officer


Copy to:-

1. The Director (Education), GNCT of Delhi, old Secretariat, New Delhi-110054.
2. Manager, Deep Parmarth Secondary School, Puran Nagar, Mehrauli Road, New Delhi-110077.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Deep Parmarth Secondary School Puran Nagar, Mehrauli Road, Palam, New Delhi-110077.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (Ground plus Two upper floors.)		
4	Details of previous NOC	F6/DFS/MS/2010/1935 Dated 30.06.2010		
5	Fire safety directives letter No	Director of Education Cir.No.262-362 dated 17.01.2005		
6	Date of inspection	19.09.2018		
7	Name of the inspecting Officers :	S.P. Bhardwaj ADO Dwarka		
8	Name and designation of officers from the building side	Mrs.Meena Sehrawat (Manager)		
9	Year of construction	Before 2010		
10	Applicant's letter No.	DPSS/18/228 dated 30.08.2018	Ground plus two upper floor	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. Dated 17.01.2005/ letter dated 30.06.2010	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.25 & 1.20 Mtrs.	1.22 & 1.20 Mtrs.	MR being old case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	One	MR
	e. Width of corridor	1.50 Mtrs.	2.37 Mtrs.	MR
	f. Door size	1 Mtr.	Provided	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		Natural Ventilation	M/R

5	Fire Extinguishers			
	total numbers	1 ABC for every 300 Sq. Mtrs.ISI	21 Nos.	MR
	Types		ABC	MR
	ISI marking		Provided	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	One each floor	Provided	M/R
	Length of Hose reel hose	30 m	Provided	M/R
	Nozzle Diameter	5 mm	Provided	M/R
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	Provided	MR
	Number of Hydrants per floor	Required	Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b.Head of main pump	N/A	N/A	N/A
	c.Number of main pumps	N/A	N/A	N/A
	d.jockey pump out put	N/A	N/A	N/A
	e.jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g.Stanby Pump head	N/A	N/A	N/A
	h.Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2.Terrace level			
	a. Discharge of pump	450 & 180 LPM	Provided	MR
	b. head of the pump	40 M	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c.Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 ltrs.	Provided	M/R
15	Exit Signage.	Required	Provided	M/R

MS

16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	DG Set	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any; ABC Fire extinguisher provided near electric Panel	MR		

Fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements as per DOE Cir. Dated 17.01.2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/2010/1935 dated 30.06.2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

Sury
20/8/18
S.P. Bhardwaj
ADO (Dwarka)

1057/DO(10)
dt. 24/09/18
DCFO(S2)



25/9
25/9
FTD
26/9

57/4652
11/11/18

FT is put up for signature please