

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/School/2018/SZ/ 2209

Dated: 28/9/18

FIRE SAFETY CERTIFICATE

Certified that the **Shri Guru Nanak Khalsa Girls Sr. Sec. School** located at Sadar Bazar, Delhi Cantt-110010, comprised of **Ground + 3 Upper floors** was inspected by officer concerned of this department on 07.06.2018 in the presence of Mrs. Neeta Bahl (Principal) of the school and found that said school building have complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi. and that the building/premises is fit for occupancy class "**Educational Building, Group-B**" as above with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 28/09/18 at New Delhi by


26/9
(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225


Copy to: -

1. Principal, Shri Guru Nanak Khalsa Girls Sr. Sec. School, Sadar Bazar, Delhi Cantt-110010.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	Shri Guru Nanak Khalsa Girls Sr. Secondary School, Sadar Bazar, Delhi Cantt-110010 (ID: 1720086)		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + 03 upper floors		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	07.06.2018		
8	Name of the Inspecting Officers	ADO Mehmood		
9	Name & Designation of Officers from the building side	Mrs. Neeta Bahl (Principal)		
10	Year of construction	1990		
11	Applicant letter No.	SGNK/DC/2017-18/371 dated 28/03/2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	Required	5 Mtr	MR
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	• Upper floors.	3 Nos	3 Nos	MR
	• Basement floor.	NA	NA	NA
	b. Width of Staircase			
	• Upper floors	1.5m / 0.90m	1.30m, 1.16m & 0.95m	MR
	• Basement floor	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	One	One	MR
	e. Width of corridor	1.5m	Provided	MR
	f. Door size	1 mtr	1 mtr	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	Natural Ventilation	NA
5.	Fire Extinguishers.			
	• Total numbers	16 Nos.	16 Nos.	MR
	• Types	ABC / Co2	ABC- 14, Co2- 2 No	MR
	• ISI Marking	ISI Marking	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Two	Two provided	MR
	• Length of hose-reel hose.	30 m	30 m	MR
	• Nozzle Diameter	5mm	5mm	MR

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA / SIREN	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	NA	NA	NA
		NA	NA	NA
13.	Pumping arrangements.			
	A. Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting / Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	B. Terrace Level			
	➤ Discharge of pump.	450 LPM	450 LPM	MR
	➤ Head of pump.	40 Mtr	40 Mtr	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 Ltr	10,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA

19.	Fire Control Room.			
	• Detector system panel.	NA	NA	NA
	• Flow switch panel.	NA	NA	NA
	• PA system panel.	NA	NA	NA
	• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA
20.	Special Fire Protection System for the Protection of special Risk, if any.	NA	NA	NA

The Fire protection systems provided in the building were randomly checked/ tested and found functional at the time of inspection. The shortcomings communicated vide letter dated 04/11/2015 have been complied.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.



Mehmood
19/6/18
Signature of the Inspecting Officer
Name : Mehmood
Designation: ADO (SJ)

DO (SD)

Anilam
24/6/18

Dy. CPO (SZ)



Krup
21/6

There is nothing on record to verify year of construction 1990. Pl ask school to provide same.

ATV

CFO S71

M. Scott

u
25/6

DCTPS2

Krup

20/6

SOX