

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



NO. F.6/DFS/MS/EH/2018/ 2205

Dated :- 28/9/2018

FIRE SAFETY CERTIFICATE

Certified that the M/S The Imperial Spice Restaurant located at M-89-90, First floor, outer circle, Connaught Place, New Delhi, comprised of Ground +2 upper but the Restaurant is running on 1<sup>st</sup> floors only was granted FSC by this department vide letter No.F6/DFS/MS/EH/2015/NDZ/1726 dated 18.09.2015. The premises was re-inspected by the officer concerned of this department on 24.09.2018 in the presence of Mr. Ravi and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules 2010 and that the premises is fit for occupancy class Assembly Building Group -D (restaurant) with effect from 28/9/18 for period of three years in accordance with Rule 36 unless under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 28/9/18 at New Delhi

  
(Vipin Cental)  
Chief Fire Officer  
Delhi Fire Service  
Ph- 011-23412225  


- Copy to:-
1. Medical Officer of Health (Health Department ),  
NDMC, Palika Kendra, New Delhi.
  2. M/S The Imperial Spice, at M-89-90, First Floor,  
outer circle, Connaught Place, New Delhi.

Following fire safety directives may be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed/unlocked & remain available for speedy evacuation of occupants in case of an emergency.  
of smooth and speedy safe evacuation of occupants in case of emergency
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.  
rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric shall be verified by the concerned building sanctioning authority.
5. The trained fire fighting staff should be available around the clock.
6. This fire safety certificate may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.

### INSPECTION REPORT

1. Name & address of the building : M/S The Imperial spice at M-89 & 90, First Floor, Outer Circle , Connaught Place, New Delhi.
2. Building is comprised of : G+2 upper floors
3. Type of Occupancy : Group – D Assembly Building (Gr.+2), Restaurant at 1<sup>st</sup> floor only
4. Type of Case : Renewal
5. Details of Previous NOC : Letter no. F6/DFS/MS/EH/2015/NDZ/1726 dated 18.09.2015
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 24/09/18.
8. Name of the Inspecting Officers: : Sunil Chawdhary (DY. Chief Fire Officer)
9. Name of the designation of Officer from the building side : Mr. Ravi
10. Year of Construction : Old
11. Applicant's letter No : 2789/dated 06.09.2018

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
	Road width	9 mtr.	12 mtr.	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	a. Number of Staircases			
	Upper Floor	02 Nos	02 Nos	MR
	Basement	N/A	N/A	N/A
	B. Width of Staircases			
	Upper Floor	93 cm & 88cm	93cm & 88cm	MR, old case
	Basement	N/A	N/A	N/A
	c. Protection of exits			
	Fire check door	N/A	N/A	N/A
	Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	N.A.	N/A	N.A.
	e. Width of Corridor	N.A.	N/A	N.A.
	f. Door Size	N.A	2 Mtr.2.4 Mtr & 1.0Mtr	MR
3	<b>Compartmentation.</b>			
	Fire check door	Required	Providing, in basement	MR
	Sealing of electrical shafts	N/A	N/A	N/A
	Fire rating of shaft door	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	Basement	30a/c per hour	N/A	N/A
	Upper floor	12a/c per hour	Exhaust fan	MR




<b>5.</b>	<b>Fire Extinguisher</b>			
	Total numbers	08 Nos.	08 Nos	MR
	Types	ABC & Wco <sub>2</sub>	Provided	MR
	IS marking	ISI	YES	MR
<b>6</b>	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	02 no.	02 Nos at first floor	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	N/A	N/A	N/A
	Location of main panel	N/A	N/A	N/A
	Location of repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided	MR
	Hooters's location	Required	Provided	MR
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9</b>	<b>Public address System.</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	size of riser/down-comer	100 mm	100 mm	MR .
	Number of hydrants per floor	01 Nos	01 Nos	MR
	Hose Box	01 Nos	01 Nos	MR .
<b>12</b>	<b>Yard Hydrants.</b>			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
<b>13</b>	<b>Pumping Arrangements.</b>			
	Ground Level	N/A	N/A	N/A
	Discharge of main Pump	N/A	N/A	N/A
	Head of Main Pump	N/A	N/A	N/A
	Number of main pumps	N/A	N/A	N/A
	Jockey pump out put	N/A	N/A	N/A
	Jockey pump head	N/A	N/A	N/A
	Standby pump out put	N/A	N/A	N/A
	Standby pump Head	N/A	N/A	N/A
	Auto Starting /Manual stopping	N/A	N/A	N/A
	Pump House Access	N/A	N/A	N/A
	Terrace Level			R
	Discharge of pump	900 LPm & 180 LPM	900 LPm & 180 LPM	MR
	Head of the Pump	40 mtr	40 mtr	MR
	Power supply	required	Provided	MR
	Auto Starting of pump	required	Provided	MR

<b>14</b>	<b>Captive Water Storage for Fire Fighting.</b>			
	Underground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	required	Provided	MR
	Access to tank	required	Provided	MR
	Overhead Tank capacity	5,000 Liters	5,000 Liter	MR
<b>15</b>	<b>Exit Signage.</b>	required	Provided	MR
<b>16</b>	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
<b>17</b>	<b>Standby power supply</b>	required	Provided	MR
<b>18</b>	<b>Refuge Area.</b>			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
<b>19</b>	<b>Fire Control Room</b>			
	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the Eating House were tested , checked random and found functional at the time of inspection.

In view of the Deemed compliance of the ~~compliance~~ of the minimum standards of fire prevention and fire safety measures as required under the Rule the FSC issued vide letter no. F6/DFS/MS/EH/2015/NDZ/1726 Dated 18.09.2015 renewal under rule 35 of the Delhi Fire Service Rule 2010/ recommended to Renew FSC please.



Signature of the Inspecting Officer  
Name Sunil Chawdhary  
Designation DY. Chief Fire Officer

CFP

m.scell

FT M.

14/09/19

51 is put up