

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/LPG/2018/SZ/ 2431

Dated: 28/10/18

FIRE SAFETY CERTIFICATE

Certified that M/s Ashoka Stores (Storage of Bharat LPG Cylinders) located at Site No-2, Amar Colony, Lajpat Nagar-IV, New Delhi-110024, comprised of Single Storey building Owned/Occupied by M/s Ashoka Stores have complied with fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by officer concerned of this department on 14/09/2018 in the presence of Mr. Nitin Thapar and that premises is fit for occupancy class "Group 'J' Hazardous Building" as above with effect from the date of issue of this certificate for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued 28/10/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225


Copy to: -

1. M/s Ashoka Stores (Distributor: Bharat Gas), K-1/51, Chittaranjan Park, New Delhi-110019
2. Administrative Officer, South MCD, South Zone, Green Park, New Delhi-110016

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	M/S Ashoka Stores (Bharatgas Storage), Site No-2, Amar Colony, Lajpat Nagar-IV, New Delhi-110024		
2	Type of Occupancy	Hazardous "Group-J" (LPG Godown)		
3	Building Comprised of	Single Storey.		
4	Type of Case	Renewal		
5	Details of Previous NOC	Old file not traceable in MS Cell / Record		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	14-09-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Nitin Thapar		
10	Year of construction	1975		
11	Applicant letter No.	Outdoor diary No. 11172 dated 02-08-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	9 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement.	-NA-	-NA-	-NA-
	b. Width of Staircase			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement	-NA-	-NA-	-NA-
	c. Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	1.0 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	Required	06 No's	MR
	• Types	ABC / Co2	ABC type	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
	• Length of hose-reel hose.	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-


M/s Ashoka Stores (Bharatgas Storage) at Site No-2, Amar Colony, Lajpat Nagar-IV, New Delhi

19.	Fire Control Room.			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A	Sand buckets filled of dry loose sand provided with stand.	N/A

The Fire protection systems provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.



 Signature of the Inspecting Officer
 Name: Mehmoed
 Design: ADO (SJ)

M/s Ashoka Stores (Bharatgas Storage) at Site No-2, Amar Colony, Lajpat Nagar-IV, New Delhi.


~~DO (SD)~~

~~where~~ where is old file.



20/9/18


SP


The old file is not traceable in all.
 Co. we put up as per your instructions
 on back side of file.



I have
changed
15/11/18
Mehmoed

~~DO (SD)~~


15/11/18

139/cfcs2
p/x.


cfcs2


15/11/18

FTD.