

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/GH/2018/SZ/ 2430

Dated: 28/10/18

FIRE SAFETY CERTIFICATE

Certified that M/s **Hotel Blue Stone** (A Unit of Rashi Apparels Pvt. Ltd) located at CC-24, Nehru Enclave, Kalkaji, New Delhi-110019, comprised of basement, ground & three upper floors (Basement: store, office & hall, Ground floor: 02 guest rooms, kitchen, reception & 04 hall, 1st Floor to 3rd Floor: 09 guest rooms on each, total: 29 guest rooms) was issued FSC by this department vide letter No. F6/MS/DFS/GH/2015/SZ/1789 dated 03/09/2015. The premise was re-inspected by officer concerned of this department on 05/10/2018 in the presence of Mr. Dhiran (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that premises is fit for occupancy class **Group-A, Residential** (Lodging or Rooming House) as above with effect from 28/10/2018 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 28/10/18 at New Delhi by

26/X.
(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225

Copy to: -

1. The Addl. Commissioner of Police (Lic.), 1st floor, P.S. Defence Colony, New Delhi-110049
2. Auth. Signatory, M/s Hotel Blue Stone at CC-24, Nehru Nagar, Kalkaji, New Delhi-19


Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	M/s Hotel Blue Stone at CC-24, Nehru Enclave, Kalkaji, New Delhi-110019		
2	Type of Occupancy	Residential, "Group-A" (Guest House)		
3	Building Comprised of	Basement, Ground + 03 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/MS/DFS/GH/2015/SZ/1589 Dated 03-09-2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	05-10-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Dhiran (Manager)		
10	Year of construction	2007	Basement (store, office & hall), Gd. floor (02 guest rooms, kitchen, hall, rec., lobby), 1 st floor (09 guest rooms), 2 nd floor (09 guest rooms), 3 rd floor (09 guest rooms) Total- 29 Guest Rooms	
11	Applicant letter No.	Outdoor Diary No. 12942 Dated 10-09-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	Provided	MR
	• Gate width	-NA-	Accessible from road	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	Required	02 nos.	MR
	➤ Basement floor.	Required	02 nos.	MR
	b) Width of Staircase			
	➤ Upper floors	Required	1.20m & 1m	MR
	➤ Basement floor	Required	1.20m & 1m	MR
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	02 nos.	MR
	e) Width of corridor	Required	1.5m	MR
	f) Door size	1m	1m (final exit)	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	• Total numbers	16 Nos	Provided	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

M/s Hotel Blue Stone at CC-24, Nehru Enclave, Kalkaji, New Delhi-110019

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	Smoke type	-NA-
		-NA-	Near Main Gate	-NA-
		-NA-	-NA-	-NA-
		-NA-	Provided	-NA-
		-NA-	Each floor	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	Provided	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	02 nos.	-NA-
		-NA-	02 nos.	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 			
		-NA-	900 LPM	-NA-
		-NA-	70m	-NA-
		-NA-	01	-NA-
		-NA-	180 LPM	-NA-
		-NA-	70m	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	450 LPM	MR
		Required	35m	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	50,000 Ltr	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		-NA-	-NA-	-NA-
		Required	10,000 Ltr	MR
		Required	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

19.	Fire Control Room. <ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			
<p>The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/MS/DFS/GH/2015/SZ/1718 dated 18-09-2015, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p>				
 Signature of the Inspecting Officer Name: Mehmood Design: ADO (SJ)				

M/s Hotel Blue Stone at CC-24, Nehru Enclave, Kalkaji, New Delhi-110019

DO (SD)

Signature
18/9/18

Signature
18/9/18

Signature
15/9



Signature
18/9/18

M. SCELL

Signature
17/9

140/cf/s2
18/9.129/18

A. B.T. put up for signature please

Signature
22/9/18
ADO (SJ)

Signature
18/9/18

M. SCELL

Signature
26/9