

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/School/2018/NDZ/ 2427

Dated: 29/10/18

FIRE SAFETY CERTIFICATE

Certified that the Sirish Public School running comprised of ground plus three upper floors at B-210,Gali No.1,Rajveer Colony Extn.,Delhi-96, owned/occupied by Sirish Public School was issued FSC by this department for ground plus two upper floors vide letter No. F6/DFS/MS/School/2015/WZ/1662Dated-14/09/15. The school building was inspected by the officer concerned of this department on 04/10/18 in the presence of Mr. Saurabh Shrivastva (Manager) of the school and found that the school building on ground plus two upper floors have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular no. 262-362 Dated 17/01/2005 and the school building GF+FF+SF is fit for occupancy class "B" 'Educational Building' with effect from ..29/10/18.. for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....29/10/18.....at New Delhi by


(Vipin Kental)
Chief Fire Officer

To,

The Principal,
Sirish Public School B-210,
Gali No.1,Rajveer Colony Extn.,Delhi-96.

Copy to:-

The Director of Education
Govt.of NCT of Delhi
Old Secretariat, Delhi-51.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT

1. Name & address of the building: Sirish Public School at B-210,Gali No.1,Rajveer Colony Extn.,Delhi-96.
2. Building is comprised of : G+3 (School at G+2 upper floor only)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/School/2015/WZ/1662Dated-14/09/15
6. Fire Safety direction letter No : Circular Director of Education dated 17.01.2005
7. Date of Inspection : 04/10/18
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of Officer from the building side : Mr. Saurabh Shrivastva (Manager)
10. Year of Construction : 1998
11. Applicant's letter No : letter No.Nil dated 08/09/18

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 M	06 M	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02 Nos	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 M	.75 M & .90 M	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1No.	1No.	MR
		1.25 M	1.25 M	MR
	g. Width of Corridor	1.0 M	1.0 M	MR
	h. Door Size			
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers.	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	6 Nos.	6 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR

N/10

6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no	Provided	MR
		30 m	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooter's location 	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> upper floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer 	100 MM	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	1No.	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	1No.	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Level 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Head of Main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Auto Starting /Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump 	450 LPM	Provided	MR
	<ul style="list-style-type: none"> Head of the Pump 	40 M	Provided	MR
	<ul style="list-style-type: none"> Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto Starting of pump 	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	5,000 Ltrs.	Provided	MR
15	Exit Signage	N/A	Provided	MR

N/A

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The school building was issued shortcomings vide letter no. F6/DFS/MS/2018/3691 dated 30/08/18 which is rectified. The same were checked and found functional at the time of inspection..

In view of deemed compliance of the minimum standards of fire prevention and fire Safety measured as required under the rules. The fire safety certificate issued vide letter no. F6/DFS/MS/School/2015/WZ/1662 Dated-14/09/15 renewal under the circular no.262-362 dated 17/01/2005 is recommended.

R. K. Yadav
4/10/18

Signature of the Inspecting Officer
Name: R. K. Yadav
Designation: ADO(LN)

DO(ED) Please attend undertaking of use of III Floor of the school building.

ADD/LN.
School is running at Ground + 2 Floor only. Third floor is residence of the owner of school.
Resubmitted please!

[Signature]
8/11

757/cr/01/18 DO(ED) *[Signature]*

R. K. Yadav
18/10/2018