

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/2018/ w2/2402

Dated: 26 /10/2018

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Bikanervala Foods Pvt. Ltd,(For 140 Seats) Located At, Plot No-7, Ground Floor & 1<sup>st</sup> Floor, Block-2, WHS kirti Nagar Industrial Area, New Delhi in a building comprised of Basement + Ground + 3<sup>rd</sup> Upper Floors Owned/ occupied by M/S Bikanervala Foods Pvt. Ltd have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 18-07-2018 in the presence of Mr. K. Mani (Area Head) and found that the said building that the premises is fit for occupancy class "Assembly" Group D with effect from 26/10/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...26/10/18.... at New Delhi by.

  
(Atul Garg),  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. M/S Bikanervala Foods Pvt. Ltd, Plot no-7, 1<sup>st</sup> Floor, Block-2, WHS kirti Nagar Industrial Area, New Delhi.
2. Dy. Health Officer, Karol Bagh Zone, NDMC, Public Health Department, Anand Pārbat, New Delhi.11005.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1. Name & address of the building : M/S Bikanervala Foods Pvt. Ltd located at Plot no-7, GF & 1<sup>st</sup> Floor, WHS kirti Nagar Industrial Area, New Delhi on Ground & First Floor.
2. Type of Occupancy : Assembly
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : As given at N/2
6. Date of inspection : 18-07-2018
7. Name of the Inspecting Officers : DO/W & ADO (WP)
8. Name and designation of officers :  
 From the building side : Mr. K. Mani (Area Head)
9. Year of Construction : 2015
10. Applicant's letter No. : Nil dated- Nil

Restaurant At-G+1<sup>st</sup> Floor  
 Basement-Vacant  
 2<sup>nd</sup> Floor-Office  
 3<sup>rd</sup> Floor- Vacant

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Required	Provided >12m	M/R
	• Gate width	Required	On Road	M/R
	• Width of internal road	N.R.	N.R.	N.R.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	2	Provided	M.R.
	• Basement	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	2 x 1.5mtr	153 cm, 135cm Provided	M/R
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	N.R.	N.R.	N.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	1	2	MR
	e. Width of Corridor	N.R.	N.R.	N.R.
	f. Door size	2 m & 1m	GF=2m & 130cm FF= 1m	M.R.
3.	<b>Compartmentation.</b>			
	• Fire check door	N.R.	N.R.	N.R.
	• Sealing of electrical shafts	N.R.	N.R.	N.R.
	• Fire Rating of shaft door	N.R.	N.R.	N.R.
	• Water Curtain	N.R.	N.R.	N.R.
	• Fire Dampers	N.R.	N.R.	N.R.



N-10

4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA	NA	NA
		Required	Provided in kitchen	M.R.
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	1 CO <sub>2</sub> , Water CO <sub>2</sub> type ISI marked	Provided Provided Provided	M.R. M.R. M.R.
6.	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30 m required 5 mm	Provided Provided Provided	M.R. M.R. M.R.
7.	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's Location</li> </ul>	Required Required Required Required Required	Provided Provided Provided Provided Provided	M.R. M.R. M.R. M.R. M.R.
8.	<b>MOEFA</b>	Required	Provided	M.R.
9.	<b>Public Address System</b>	N.R.	Provided	M.R.
10.	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N.A. N.R. N.R.	N.A. Provided N.R.	N.A. N.R. N.R.
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	150 m. m 01 01	Provided Provided Provided	M.R. M.R. M.R.
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N.R. N.R.	N.R. N.R.	N.R. N.R.

<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump Hose Access	NA	NA	NA
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	40 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<b>Underground tank capacity</b>	NA	NA	NA
	➤ Draw -off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	➤ Overhead Tank Capacity	25,000 ltrs	Provided	M.R.
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M.R.
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	M.R.
<b>18.</b>	<b>Refuge Area</b>			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.



N-12

19.	Fire Control Room			
	➤ Detector System Panel	N.R	N.R	N.R
	➤ Flow Switch Panel	N.R	N.R	N.R
	➤ PA system Panel	N.R	N.R	N.R
	➤ Batter backup	N.R	N.R	N.R
	➤ Building Floor plans	N.R	N.R	N.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.R	N.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers .....NIL.....

Note:-

1. The area of 1<sup>st</sup> floor;-314m<sup>2</sup>. After deducting area of lift and staircase (37.46 m<sup>2</sup>),The total area of restaurant at 1<sup>st</sup> Floor 276.54m<sup>2</sup>.
2. As per NBC Part -IV, the number of seats comes out to be approx. (276.54/1.8= 153.63).
3. The width of two staircases provided on the site are 153cm & 135 cm, the total width come out 288cm which meet the requirement as per NBC -IV for 288 seats. The FSC is recommended for 140 seats.
4. All the shortcomings communicated vide letter no - F6/DFS/MS/2018/2803 Dated-29/06/2018 has been complied.

*Udaivir Singh*  
 Signature of the Inspection Officer  
 Name:Udaivir Singh  
 Designation ADO/WP

*Sh Mukesh Verma*  
 Signature of the Inspection Officer  
 Name Sh Mukesh Verma  
 Designation DO/W

*Dy ADO/WP*

*what about fire*

*Do not work*

*FCD is not req. as the kitchen is open.*

*[Signature]*  
 18/8/18