

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZ/ 2253

Dated: 05/10/18

FIRE SAFETY CERTIFICATE

Certified that the M/s EDMC Primary Boys School at New Seelampur (South Zone) Delhi-110053, comprised of ground plus two upper floors owned / occupied by M/s EDMC Primary Boys School. The school building was re-inspected by the officer concerned of this department in presence of Principal of the school and found that the school building have complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from05/10/18..for a period three year, subject to conditions printed overleaf.

Issued on.....05/10/18.....at New Delhi by


10/18
(Vipin Kental)
Chief Fire Officer

qe
ok

To,
The Principal
M/s EDMC Primary Boys School,
1st shift, New Seelampur (South Zone),
Delhi -110053.

Copy to:-

1. The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi- 110053.
2. The Principal
M/s EDMC Primary Boys School,
2nd shift, New Seelampur (South Zone),
Delhi -110053.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3 All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4 The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
- 5 This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

- 115
1. Name & address of the building : EDMC Primary Boys School, Marginal Bandh New, New Seelampur (South Zone), Delhi -110053.
 2. Building is comprised of : Ground + 2
 3. Type of Occupancy : Educational
 4. Type of Case : New
 5. Details of Previous FSC letter : N/A
 6. Fire Safety circular No : Delhi Fire Service Act, 2007 and Rules 2010.
 7. Date of Inspection : 15/09/18
 8. Name of the Inspecting officers : ADO Omprakesh
 9. Name and designation of Officer from the building side : Smt Seema Rani (Principal)
 10. Year of Construction : 2005
 11. Applicant's letter No : NIL Dated - 21/08/2018

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remark MR/NMR
1	Access to building	06 Mtrs	06 Mtrs	MR
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road			
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	01 no.	01 no.	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	b. Width of Staircases	1.50 mtr	1.50 mtr	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	01 no.	01 no.	MR
	d. No. of continuous staircases to terrace	1.5 m	1.50 m	MR
	e. Width of Corridor	1.0 m	1.0 m	MR
	f. Door Size			
3	Compartmentation.	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• Upper floor			
5.	Fire Extinguishers	06 nos.	06 nos.	MR
	• Total numbers	ABC & Co2	ABC & Co2	MR
	• types	ISI marked	ISI marked	MR
	• ISI marking			

6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	Provided	MR
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Required	MR
	➤ Auto Starting of pump	Required	Required	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltrs	10,000 Ltrs	MR
15	Exit Signage.	Required	Required	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the DFS Act, 2007 and rules 2010. The Fire safety is recommended to Issue under rule 35 of the Delhi Fire Service Rule 2010.

Om Prakash
17/9/18

Signature of the Inspecting Officer
Name : - Om Prakash
Designation : - ADO (Shahdara)

DO (East) *[Signature]*
17/9/18

718/CF/S2
20/9

DCFO/MDZ *[Signature]*

CT. Q. m.scell FT/DT
11/20/19

Sir, F.T. Letter is put up for your kind signature please.

e.f.o (MDZ)

Om Prakash
26/9/18

m.scell 11/20/19