

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/FW/2018/SZ/ 2407

Dated: 26/10/18

FIRE SAFETY CERTIFICATE

Certified that M/s **Gyan Chand Fire Works** situated at Shop No-1730/2 (Ground floor), Gurudwara Road, Kotla Mubarakpur, New Delhi-110003, comprised of ground plus two upper floor was issued FSC by this department vide letter No. F6/DFS/MS/FW/2013/387 dated 29/05/2013. The fireworks shop was re-inspected by officer concerned of this department on 06/10/2018 in the presence of Sh. Gyan Chand (Partner) and found that the said premises have deemed complied with the guidelines issued by Delhi Police under Delhi Police Act and that premises is fit for occupancy class "**Fire Works**" with effect from 26/10/18 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/10/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225


Copy to: -

1. The Addl. Commissioner of Police (Lic.), 1st floor, P.S. Defence Colony, New Delhi-110049
2. M/s Gyan Chand Fire Works at Shop No-1730/2 (Gd. floor), Gurudwara Road, Kotla Mubarakpur, New Delhi-110003

Conditions for the validity of Fire Safety Certificate:


1. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection.
2. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire-fighting staff should be available round the clock when shop is functional.
4. Any deviation w.r.t. construction etc shall be verified by the concern building sanctioning authority.
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.

INSPECTION REPORT

1	Name & Address of the Building	M/s Gyan Chand Fire Works at Shop No-1730/2, Gurudwara Road, Kotla Mubarakpur, New Delhi-110003		
2	Type of Occupancy	Fireworks (Sale and Possession of Fireworks) (100 Kg Fireworks & 500 Kg Chinese Crackers/Sparklers)		
3	Type of Case	Renewal		
4	Details of Previous NOC	F.6/DFS/MS/FW/2013/387 dated 29-05-2013		
5	Fire Safety Directives Letter No	Nil		
6	Date of Inspection	06-10-2018		
7	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
8	Name of person from building side	Sh. Gyan Chand		
9	Year of construction	N/A	Ground + 02 upper floors.	
10	Applicant letter No.	Outdoor Diary No. 13127 dated 13-09-2018		
S. No.	Points of Inspection	Requirement	Provided at Site	Remarks MR/NMR
1	Type of construction, floor area & floor level.			
	a. Minimum floor area.	9m ²	20' x 9' = 16.44m²	MR
	b. Construction.	Pucca	Provided	MR
	c. Premises location.	Not under staircase/ means of escape	Provided	MR
	d. Business permissible only at ground level.	Required	Provided	MR
	e. Business from pavement of road prohibited.	Prohibited	Provided	MR
2	Entrance & Exits to the Licensed Premises			
	The Licensed premises shall have independent entrance and exit	Required	Provided	MR
3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15m from any premises used for similar explosive / inflammable or hazardous material.	Required 15m	Provided	MR
4.	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be for possession and sale of firework and no other purpose	Required	Provided	MR
5	Type of electrical wiring & electrical fitting			
	a. Preferably concealed or through conduit.	Required	Provided	MR
	b. All electrical fitting should be flame/spark proof	Required	Provided	MR
6	Extension of shop for business.			
	Prohibited	Prohibited	Provided	MR
7	Approach Road			
	The road width on the side of which premises is located should be 12m	12m	Provided	MR
8	Fire Protection Arrangement			
	a. Extinguisher Type & Nos.	2 nos. of Water type & 01 no. of ABC/Co2	Provided	MR
	b. Sand and water buckets	2 nos. each	Provided	MR
	c. Water Drum	1 no.	Provided	MR
9	Any other point that is contrary to the safety of people			-NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/FW/2013/387 dated 29/05/2013, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.



DO (SD)

[Handwritten Signature]
17/10/18

[Handwritten Signature]
Signature of Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

FT 101