

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/FW/2018/SZ/ 2408

Dated: 26/10/18

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Standard Pataka Bazar** situated at Shop No-43/6 (Ground floor), Subhash Market, Kotla Mubarakpur, New Delhi-110003, comprised of ground + one upper floor was issued FSC by this department vide letter No. F6/DFS/MS/SZ/2013/488 dated 27/06/2013. The fireworks shop was re-inspected by officer concerned of this department on 06/10/2018 in the presence of Mr. Anand Sharma (Partner) and found that the said premises have deemed complied with the guidelines issued by Delhi Police under Delhi Police Act and that premises is fit for occupancy class "**Fire Works**" with effect from \_\_\_\_\_ for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on \_\_\_\_\_ at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Ph: 011-23412225  


Copy to: -

1. The Addl. Commissioner of Police (Lic.), 1<sup>st</sup> floor, P.S. Defence Colony, New Delhi-110049
2. Proprietor, M/s Standard Pataka Bazar at Shop No-43/6 (GF), Subhash Market, Kotla Mubarakpur, New Delhi-110003

**Conditions for the validity of Fire Safety Certificate:**


1. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection.
2. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire-fighting staff should be available round the clock when shop is functional.
4. Any deviation w.r.t. construction etc shall be verified by the concern building sanctioning authority.
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.

## INSPECTION REPORT

1	Name & Address of the Building	M/s STANDARD PATAKA BAZAR at Shop -43/6, Subhash Market, Kotla Mubarakpur, New Delhi-110003		
2	Type of Occupancy	Fireworks (Sale and Possession of Fireworks) (300 Kg Fireworks & 1200 Kg Chinese Crackers/Sparklers)		
3	Type of Case	Renewal		
4	Details of Previous NOC	F.6/DFS/MS/FW/2013/488 dated 27-06-2013		
5	Fire Safety Directives Letter No	Nil		
6	Date of Inspection	06-10-2018		
7	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
8	Name of person from building side	Mr. Anand Sharma		
9	Year of construction	N/A		
10	Applicant letter No.	Outdoor Diary No. 13126 dated 13-09-2018		
S. No.	Points of Inspection	Requirement	Provided at Site	Remarks MR/NMR
1	<b>Type of construction, floor area &amp; floor level.</b>			
	a. Minimum floor area.	9m <sup>2</sup>	14.9 x 11.9=16.2m <sup>2</sup>	MR
	b. Construction.	Pucca	Provided	MR
	c. Premises location.	Not under staircase/ means of escape	Provided	MR
	d. Business permissible only at ground level.	Required	Provided	MR
	e. Business from pavement of road prohibited.	Prohibited	Provided	MR
2	<b>Entrance &amp; Exits to the Licensed Premises</b>			
	The Licensed premises shall have independent entrance and exit	Required	Provided	MR
3	<b>Type and distance of the surrounding risk</b>			
	The premises shall be situated at a distance of 15m from any premises used for similar explosive / inflammable or hazardous material.	Required 15m	Provided	MR
4.	<b>Nature of business run in the licensed premises</b>			
	The premises in which fireworks are kept shall be for possession and sale of firework and no other purpose	Required	Provided	MR
5	<b>Type of electrical wiring &amp; electrical fitting</b>			
	a. Preferably concealed or through conduit.	Required	Provided	MR
	b. All electrical fitting should be flame/spark proof	Required	Provided	MR
6	<b>Extension of shop for business.</b>			
	Prohibited	Prohibited	Provided	MR
7	<b>Approach Road</b>			
	The road width on the side of which premises is located should be 12m	12m	Provided	MR
8	<b>Fire Protection Arrangement</b>			
	a. Extinguisher Type & Nos.	2 nos. of Water type & 01 no. of ABC/Co2	Provided	MR
	b. Sand and water buckets	2 nos. each	Provided	MR
	c. Water Drum	1 no.	Provided	MR
9	<b>Any other point that is contrary to the safety of people</b>			

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/SZ/2013/488 dated 27/06/2013, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.



DO (SD)

*Anand Sharma*  
10/10/18

*Mehmood*


*Mehmood*  
13/10/18  
Signature of Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)

-N/4-

**GRANT OF NOC FOR SALES STORAGE OF FIRE WORKS**  
(In areas other than walled city & congested areas)

**INSPECTION REPORT (PART A)**  
(To be filled in Duplicate by the inspecting officer)

- |    |   |  |
|----|---|--|
| 1. | Name & Address of The License   | Shri Anand Sharma S/o Shri C.L. Sharma<br>R/o 491, Gurdwara Road, Kotla<br>Mubarakpur, New Delhi.  |
| 2. | Address of the Licensed Premises  | Standard Phataka Bazaar, Shop No.<br>43/6, Subhash Market, Kotla Mubarak Pur, New<br>Delhi-110003. |
| 3. | Licence No. and Validity Period   | NOC issued vide office letter<br>No.F5/(3A)/DFS/2005/266 dated 17/06/2005                          |
| 4. | Authority by which Licence was issued last                                    |  |
| 5. | Name & Designation of the Inspecting officer                                  | S.S. Kaushik (Asstt. Div. officer)   |
| 6. | Date & Time of Inspection   | (06/06/13)   |
| 7. | Period for which licence is Renewal to be renewed and the authorized quantity |  |
| 8. | Recommendations of the  |  |
| 9. | Inspecting officer for issue/rejection of NOC with reasons                    | Recommended for the renewal  |

  
(Signature of Inspection Officer)  
Designation Asst. Div. Officer

Remarks of D.O. *Recommended for renewal*

Remarks of Dy. C.F.O (South) *17/06/13*

Remarks of C.F.O.

Issue NOC \* / Reject

- NOC is issued subject to condition that status quo shall be maintained and the Conditions laid down under Indian Explosive rules 1983/ conditions laid down by MCD/ Police are complied with.

Date:

Director  
Delhi Fire Service

*Where is inspection report?*

*17/6*