

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/BH/2018/WZ/ 2387

Dated: 25/10/18

FIRE SAFETY CERTIFICATE

Certified that the **SUBH NIMANTRAN BANQUETS** located at 7/25, Kirti Nagar, Industrial Area, New Delhi-110015 comprised of Basement, Ground Floor, 1st Floor, 2nd Floor & 3rd Floor (Temporary shed) Only owned / occupied by **SUBH NIMANTRAN BANQUETS** has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/BNQT/2013/WZ/523 dated 08/07/2013. The premises was re-inspected by the officers concerned of Fire Service on 16.10.2018 in the presence of Sh. Sunil (Partner) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with NBC (Part-IV) and that the building / premises is fit for occupancy class **Assembly (Banquet Hall)** with effect from 25/10/2018 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on25/10/18..... at New Delhi.


(ATUL GARG)

CHIEF FIRE OFFICER.

Copy to :-

1. Authorized Signatory, Subh Nimantran banquets located at 7/25, Kirti Nagar, Industrial Area, New Delhi-110015.
2. Dy. Health Officer, Karol Bagh Zone, NDMC, Public Health Department, Karol Bagh, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

Basement + Ground Floor + 1st Floor + 2nd Floor & 3rd Floor (Temporary shed) Only

1. Name & address of the building: **SUBH NIMANTRAN BANQUETS**, 7/25, Kirti Nagar, Industrial Area, New Delhi.
2. Type of Occupancy : **Assembly** (Banquet Hall)
3. Type of Case : **Renewal**
4. Details of previous NOC : F6/DFS/MS/BNQT/2013/WZ/523 dated 08/07/2013
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2012/2815 dated 31/07/2012
6. Date of inspection : 16/10/2018
7. Name of the Inspecting Officer : A.D.O. (Jwala Puri) & D.O. (West)
8. Name and designation of Officer
from the building side : Mr. Sunil (Partner)
9. Year of Construction : 2009
10. Applicant's letter No. : - Nil dated 19/09/2018

S. No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	12 mtr	MR
	• Gate width	5 mtr	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	1.50 mtr	2X1.50 Mtr	MR
	• Basements	1.50 mtr	2X1.50 Mtr	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	2 mtr	2 mtr	MR
	f. Door Size	2 mtr & 1 mtr	GF-2x2.14m&1x1m FF-2.14m & 1.1m SF-2.14m & 1.38m	MR
3.	Compartmentation			
	• Fire check door	Required in basement	Provided	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	8	8	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R

6.	• First - Aid Hose Reels	2	2	MR
	• Total numbers on each floor	2		
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
7.	• Nozzle diameter	5mm	5mm	MR
	Automatic fire detection and alarming system			
	• Type of detector	Smoke	Provided	MR
	• Location of Main Panel	GF	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
8.	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	All strategic locations	Provided	MR
9.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
11.	• Sprinkler above false ceiling	NA	NA	NA
	Internal Hydrants			
	• Size of riser/down-comer	150 mm	150 mm	MR
12.	• Number of hydrants per floor	2	2	MR
	• Hose Box	2	2	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
13.	• Hose Box	NR	NR	NR
	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 LPM	2280 LPM	MR
	➤ Head of main pump	60 MH	60 MH	MR
	➤ Number of main pumps	1	1	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	70 MH	70 MH	MR
	➤ Standby Pump out put	2280 LPM	2280 LPM	MR
	➤ Standby Pump Head	60 MH	60 MH	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
➤ Discharge of pump	900 LPM	900 LPM	MR	
➤ Head of the pump	50 MH	50 MH	MR	
➤ Power supply	Required	Provided	MR	
➤ Auto starting of pump	Required	Provided	MR	
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	50,000 ltr.	50,000 ltr	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR

		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note :- Shortcomings issued by this department vide letter No. F6/DFS/MS/BANQT/2018/1179 dated 21/03/2018 have been complied.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/BNQT/2013/WZ/523 dated 08/07/2013 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation : A.D.O. (Jwala Puri)

Signature of the Inspecting Officer
 Name : Mukesh Verma
 Designation : D.O. (West)

(Handwritten signatures and dates)
 17/X/2018
 18/10/17
 18/10/18

(Handwritten signature and date)
 18/10/18