

431

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/2015/52/1859

Dated: 16/10/15

FIRE SAFETY CERTIFICATE

Certified that the M/S New Building of Vishwa Yuvak Kendra, located at Circular Road, Chanakyapuri, New Delhi-110021, comprised of basement, ground plus three upper floors only, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2012/3054, dated 23-08-12. The premises was re-inspected by the officer concerned of this department on 06-10-2015 in the presence of Sh. B.S.Rathore (Hostel Supervisor) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class A "Residential Dormitory Building" with effect from 16/10/15 2015 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/10/15 2015 at New Delhi by.


16/10/15

(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

Copy to:- Sh. Uday Shankar Singh, Chief Controller, Vishwa Yuvak Kendra, Circular Road, Chanakyapuri, New Delhi-110021. o/c

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S New Building of Vishwa Yuvak Kendra, Circular Road, Chanakyapuri, New Delhi-110021.
2. Building comprised of : B+G+3Upper floors.
3. Type of Occupancy : Group "A" Residential Dormitory Building.
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F6/DFS/MS/2012/3054, dated 23.08.12.
6. Fire Safety direction letter No : No.F6/DFS/MS/2007/1681, Dated 22.06.2007.
7. Date of Inspection : 06.10.15.
8. Name of the Inspecting Officers: : Vedpal (ADO).
9. Name and designation of Officer from the building side : Sh. B.S.Rathore(Hostel Supervisor).
10. Year of Construction : 2010.
11. Applicant's letter No : No.VYK/CC/2015, dated 21.07.15.

S.No	Minimum Standards on fire prevention and fire safety as per Rule 33.	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	10m	MR
	Gate width	4.5m.	4.5m.	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	2nos.	2nos.	MR
	Basement	02nos	02nos.	MR
	B. Width of Staircases	.		
	Upper Floor	1.25m(two)	1.5m (each)	MR
	Basement	1.25m	1.5m & 1.37m	MR
	c. Protection of exits	Required	Provided	MR
	Fire check door	Required	Provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1no.	1no.	MR
g. Width of Corridor	N.A.	N.A.	N.A.	
h. Door Size	1mtr.	1mtr.	MR	
3	Compartmentation			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust fan Provided	MR
	Upper floor	15 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguisher			
	Total numbers	20 nos.	24 nos.	MR
	Types	ABC&WCO ₂	ABC&WCO ₂	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01no.	01no.	MR.
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5cm	5cm	MR.

N/10
M/S Vishwa Yuvak Kendra, Circular Road, Chanakyapuri, New Delhi-21.

7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	M R
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450LPM	450 & 180 LPM	MR
	➤ Head of the Pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	5000Liters	10000Liters	MR
15	Exit Signage.	Required	Provided	M R

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	Required	Provided	M R
	Firemen's grounding switch	Required	Provided	M R
	Lift Signage	Required	Provided	M R
17	Standby power supply	Required	Provided (DG Set)	M R
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Battery backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the Fire Safety Certificate issued vide letter No.F.6/DFS/MS/2012/3054, dated 23.08.12, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for kind consideration please.

[Signature] 11/10/15

Signature of the Inspecting Officer

Name Vedpal

Designation ADO

[Signature]
12/10/15

D.O.(South)

Dy.C.F.O. (South Zone)

[Signature]
12/10/15



[Signature]
13/10/15

[Signature]
13/10/15

[Signature]

[Signature]
14/10/15

F.T
14/10/15