

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI

No.F6/DFS/MS/School/2017/WZ/ 2302

Dated: 12 / 10/2018

FIRE SAFETY CERTIFICATE

Certified that the **Pioneer Convent Sr. Sec. School** located at Lok Nayak Puram, Bakkarwala, New Delhi-110041, comprised of Ground + 01 Upper Floors was issued FSC vide Letter No. **F6/DFS/MS/School/2015/WZ/1949 dated 30/10/15**. The premises was re inspected by the officers concerned of this department on **08.10.2018** in the presence of **Mr. Saurabh Awasthi (Administrative Officer)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular GNCT of Delhi vide letter no. 3298-3398 dated 01.03.2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 12/10/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/10/18 at New Delhi by.

(Atul Garg)
Chief Fire Officer,

Copy to:

1. Dr. Seema Bajaj (Principal)
Pioneer Convent Sr. Sec. School located at Lok Nayak Puram, Bakkarwala, New Delhi-110041.
2. The Director of Education, Old Secretariat, Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT


1. Name & address of the building: **Pioneer Convent Sr. Sec. School** located at Lok Nayak Puram, Bakkarwala, New Delhi-110041.
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : **F6/DFS/MS/School/2015/WZ/1949 dated 30/10/15**
5. Fire Safety directives Letter No. : DOE Circular 3298-3398 dated 01.03.2011
6. Date of inspection : 08-10-2018
7. Name of the Inspecting Officer : Mukesh Verma, DO (West)
8. Name and designation of Officer
from the building side : Mr. Saurabh Awasthi (Administrative Officer)
9. Year of Construction : 2006
10. Applicant's letter No. : Form 'J' Dated 25.09.2018

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE. Cir. Dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible Accessible NA 	<ul style="list-style-type: none"> Provided Provided NA 	<ul style="list-style-type: none"> MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 1 NA 	<ul style="list-style-type: none"> 2 Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 1.5 mtr NA 	<ul style="list-style-type: none"> 155 cm, 80 cm NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NR NR 	<ul style="list-style-type: none"> NR NR 	<ul style="list-style-type: none"> NR NR
	d. No of continuous staircase to terrace			
	<ul style="list-style-type: none"> • No of continuous staircase to terrace 	<ul style="list-style-type: none"> 1 	<ul style="list-style-type: none"> Provided 	<ul style="list-style-type: none"> MR
	e. Width Of Corridor			
	<ul style="list-style-type: none"> • Width Of Corridor 	<ul style="list-style-type: none"> 1.5 mtr 	<ul style="list-style-type: none"> 1.5mtr Provided 	<ul style="list-style-type: none"> MR
	f. Door Size			
	<ul style="list-style-type: none"> • Door Size 	<ul style="list-style-type: none"> 1 mtr 	<ul style="list-style-type: none"> Provided 	<ul style="list-style-type: none"> MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<ul style="list-style-type: none"> NR NR NR NR NR 	<ul style="list-style-type: none"> NR NR NR NR NR 	<ul style="list-style-type: none"> NR NR NR NR NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	<ul style="list-style-type: none"> 06 nos. ABC & CO₂ ISI marked 	<ul style="list-style-type: none"> 12 nos. Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
6.	First – Aid Hose Reels			

7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
		NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	100 mm	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NR	450lt/min	NR
	➤ Head of the pump	NR	40 mtr	NR
	➤ Power supply	NR	Provided	NR
	➤ Auto starting of pump	NR	Provided	NR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NR	NR	NR
	➤ Draw off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	NR	2500 ltrs	NR
15	Exit Signage			
		NA	Provided	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply			
		NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Battery backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/School/2015/WZ/1949 dated 30/10/15 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.


Signature of the Inspecting Officer

Name : Mukesh Verma

Designation : DO (West)


~~DO CFO (WZ)~~
~~CFO WEST~~
~~19/10/18~~


राजेश

FRAS

DO/W F.T./FSC is put up for signature please.

~~CFO (WZ)~~
~~14/10/18~~


14/10/18

M