

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZ/ 2344

Dated: 17/10/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Gyan Bharti Public School, X-3510, Raghupura – II, Gandhi Nagar, Delhi -31 comprised of ground plus two upper floors owned / occupied by Gyan Bharti Public School was issued FSC vide letter No. F.6/MS/DFS/2006/1348 Dated 19/06/2006. The school building was re-inspected by the officer concerned of this department in presence of Sh. T. L. Aggarwal, Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262-362 dated 17/01/2005 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from ...17/10/18...for a period three year, subject to conditions printed overleaf.

Issued on.....17/10/18.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

To,  
The Manager  
M/s Gyan Bharti Public School,  
X-3510, Raghupura – II,  
Gandhi Nagar, Delhi -31.

Copy to:-  
The Director of Education,  
East Delhi Municipal Corporation,  
419, Udyog Sadan, Patparganj Industrial Area,  
Delhi- 110092.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3 All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4 The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
- 5 This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 7 "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

- NIL
1. Name & address of the building : Gyan Bharti Public School,  
X-3510, Raghupura – II, Gandhi Nagar, Delhi -31.
  2. Building is comprised of : Ground plus two upper floors
  3. Type of Occupancy : Educational
  4. Type of Case : Renewal
  5. Details of Previous FSC letter : F.6/MS/DFS/2006/1348 Dated 19/06/2006
  6. Fire Safety circular No (Old requirements)  
Circular No. 262-362 dated 17/01/05 issued by DoE
  7. Date of Inspection : 25/09/18
  8. Name of the Inspecting officers : ADO Omprakesh
  9. Name and designation of Officer  
from the building side : Sh. T.L. Aggarwal(Manager)
  10. Year of Construction : 1980
  11. Applicant's letter No : Nil Dated – 05/09/2018

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	06 Mtrs	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 no.	02 no.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases	N/A	N/A	N/A
	• Upper Floor	1.50 mtr	1.10 m, & 0.90 m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 no.	01 no.	MR
	e. Width of Corridor	1.5 m	1.50 m	MR
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	06 nos.	06 nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR



6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	220 LPM	450 LPM	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	Required	Required	MR
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 Ltrs	5000 Ltrs	MR
15	Exit Signage.	Required	Required	MR

N14

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the circular No. 262-362 dated 17/01/2005 is recommended to renew Fire Safety Certificate.

*Om Prakash*  
27/9/18

Signature of the Inspecting Officer  
Name :- Om Prakash  
Designation :- ADO (Shahdara)

DO (East)

*on cell*

DCFO/NDZ

*[Signature]*

*C.F.R*

*M.Scell*

*FT/OT*

*U/ITX*

Sir, F.T. letter is put up for your kind signature please.

C.F.O (NDZ)

*[Signature]*

*M:scell*

*U/10/X*

*Om Prakash*

9/10/18

*222/CP/NDZ  
8/10/18  
17/18*